



Addendum No. 1

City of Coquitlam

RFP No. 24-012

Victoria & Ranch Park Backstop & Fencing Replacements

Issue Date: May 7, 2024

Total Page Count: 1

Proponents shall note the following amendments to the RFP documents:

QUESTIONS AND CLARIFICATIONS

Q1. The drawings spec a post size of 141mm which is not a standard size in Canada. The next closest standard sizes in Canada are 114mm and 168mm. Would these be acceptable instead? More so the 114mm?"

A1. The two acceptable alternative options are:

- 1. 114mm dia schedule 40 High Strength (50ksi)**
- 2. 168mm dia schedule 40 (35ksi)".**

End of Addendum No. 1

Proponents take into account the content of this Addendum in the preparation and submission of the Proposal which will form part of the Contract and should be acknowledged on the Proposal Submission Form.

Upon submitting a Proposal, Proponents are deemed to have received all addenda that are issued and posted on the City's website and considered the information for inclusion in the Proposal Submission.

Issued by:

M. Pain
Purchasing Manager
bid@coquitlam.ca