



Addendum No. 4

City of Coquitlam

RFP No. 23-010

Alarm System Monitoring

Issue Date: January 27, 2023

Total Page Count: 146

Proponents shall note the following amendments to the RFP documents:

QUESTIONS AND CLARIFICATIONS

Q1) How should pricing for the one-time alarm takeover costs be listed? Should we add this as a lump sum cost to the entire project or on a site-by-site basis?

A1) A one-time lump sum cost is acceptable for any Work needed for alarm takeover.

Q2) Please provide the number of zones per account to accurately account for the takeover/ testing of zones.

A2) See attached Site Database Report.

End of Addendum No. 4

Proponents take into account the content of this Addendum in the preparation and submission of the Proposal which will form part of the Contract and should be acknowledged on the Proposal Submission Form.

Upon submitting a Proposal, Proponents are deemed to have received all addenda that are issued and posted on the City's website and considered the information for inclusion in the Proposal Submission.

Issued by:

M. Pain
Purchasing Manager

bid@coquitlam.ca

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
961	CITY OF COQUITLAM 644 POIRIER STREET 2ND FLR - GOAL LEARNING CENTRE COQUITLAM, BC V3B 7N2	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 221957			System Type V128 Vista 128					
ATI Hours			Minutes			ATI Late Event#		
Alt ATI Hours			Minutes			Active Date 11/2/2020		
ATI Option						ATI Global		
						ATI Page		
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
2	Alarm	Back Door			CIE134-Entry/Exit			
			N					
3	Alarm	Back Door Motion			CIE132-Interior			
			N					
4	Alarm	Front Door			CIE134-Entry/Exit			
			N					
6	Alarm	Main Classroom Motion			CIE132-Interior			
			N					
7	Alarm	Main Hall Motion			CIE132-Interior			
			N					
O/C	Armed				SE-05-LOG ONLY CLOSE			
	1		N					
O/C	Disarm				SE-04-LOG ONLY OPEN			
	1		N					

CS# 281722		System Type		ANETG Alarmnet GSM Radio				
ATI Hours		26	Minutes		ATI Late Event#		G-NOTT	Active Date 11/2/2020
Alt ATI Hours		Minutes		ATI Global				
ATI Option		2-Timer Test Only		ATI Page				
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?	Equipment	Type	
2	Alarm	Back Door					CIE134-Entry/Exit	
					N			
3	Alarm	Back Door Motion					CIE132-Interior	
					N			
4	Alarm	Front Door					CIE134-Entry/Exit	
					N			
6	Alarm	Main Classroom Motion					CIE132-Interior	
					N			
7	Alarm	Main Hall Motion					CIE132-Interior	
					N			
O/C	Armed						SE-05-LOG ONLY CLOSE	
	1				N			
O/C	Disarm						SE-04-LOG ONLY OPEN	
	1				N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000071	CITY OF COQUITLAM 500 MARINER WAY WATER SERVICE BUILDING COQUITLAM, BC V3K 6C4	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer#	First to Last	CS#	First to Last	Corporate Account	2026
Gen Dispatch	Permanent	Effective Date	8/17/2009 00:00	Expire Date	

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 223187			System Type V250 Vista 250					
ATI Hours 26 Minutes			ATI Late Event# G-NOTT			Active Date 8/7/2009		
Alt ATI Hours Minutes			ATI Global					
ATI Option 2-Timer Test Only			ATI Page					
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
1	Alarm	UCC PANIC BUTTON			97-HOLD UP ALARM			
			Y					
2	Alarm	LUNCH ROOM PANIC BUTTON			97-HOLD UP ALARM			
			Y					
10	Alarm	FRONT ENTRY MOTION			CIE132-Interior			
			N					
11	Alarm	FRONT ENTRY DOOR LEFT			CIE131-Perimeter			
			N					
12	Alarm	FRONT ENTRY DOOR RIGHT			CIE131-Perimeter			
			N					
13	Alarm	MEETING ROOM BY FRONT ENTRY MO			CIE132-Interior			
			N					
14	Alarm	FRONT LOBBY MOTION			CIE132-Interior			
			N					
15	Alarm	FRONT LOBBY STAIRWELL DOOR			CIE131-Perimeter			
			N					
17	Alarm	RECEPTION TO OFFICE MOTION			CIE132-Interior			
			N					
18	Alarm	MAIN FLOOR NORTH HALL EXIT DOOR			CIE131-Perimeter			
			N					
19	Alarm	MAIN FLOOR NORTH EXIT MOTION			CIE132-Interior			
			N					
20	Alarm	MAIN FLOOR SOUTH HALL DOOR			CIE131-Perimeter			
			N					
21	Alarm	MAIN FLOOR HALL MOTION			CIE132-Interior			
			N					
22	Alarm	CARPENTRY FRONT RIGHT MANDOOR			CIE131-Perimeter			
			N					
23	Alarm	CARPENTRY FRONT RIGHT MOTION			CIE132-Interior			
			N					
24	Alarm	CARPENTRY ROOF HATCH			CIE131-Perimeter			
			N					
25	Alarm	CARPENTRY RIGHT OHD			CIE131-Perimeter			
			N					
26	Alarm	SIGN SHOP EXIT DOOR			CIE131-Perimeter			
			N					
27	Alarm	SIGN SHOP MOTION			CIE132-Interior			
			N					
28	Alarm	SIGN SHOP OHD			CIE131-Perimeter			
			N					
29	Alarm	CARPENTRY MOTION LEFT			CIE132-Interior			
			N					
30	Alarm	CARPENTRY LEFT MANDOOR			CIE132-Interior			
			N					
31	Alarm	CARPENTRY LEFT OHD			CIE131-Perimeter			
			N					
32	Alarm	STORES MANDOOR ENTRY			CIE131-Perimeter			
			N					
33	Alarm	STORES ENTRY MOTION			CIE132-Interior			
			N					

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
34	Alarm	ELECTRICAL ROOM MOTION	N		CIE132-Interior	
35	Alarm	ELECTRICAL ROOM MANDOOOR	N		CIE131-Perimeter	
36	Alarm	SOUTH STAIRWELL TO STORES LOWEI	N		CIE132-Interior	
37	Alarm	NORTH STAIRWELL NORTH MOTION	N		CIE132-Interior	
38	Alarm	CAGE DOOR IN STORES BY ELECTRICI	N		CIE131-Perimeter	
39	Alarm	STORES DOOR BY SOUTH EXIT	N		CIE131-Perimeter	
40	Alarm	STORES DOOR BY ELEVATOR	N		CIE131-Perimeter	
41	Alarm	LOWER SOUTH EXIT DOOR LEFT	N		CIE131-Perimeter	
42	Alarm	LOWER SOUTH EXIT DOOR RIGHT	N		CIE131-Perimeter	
43	Alarm	SOUTH STAIRWELL TO BAYS LOWER M	N		CIE132-Interior	
44	Alarm	SOUTH STAIRWELL LOWER MOTION	N		CIE132-Interior	
45	Alarm	STORES OHD	N		CIE131-Perimeter	
46	Alarm	STORES MOTION BY OHD	N		CIE132-Interior	
47	Alarm	BAY 2 MANDOOOR LEFT	N		CIE131-Perimeter	
48	Alarm	BAY 2 MOTION	N		CIE132-Interior	
49	Alarm	BAY 2 MANDOOOR RIGHT	N		CIE131-Perimeter	
50	Alarm	BAY 2 OHD	N		CIE131-Perimeter	
51	Alarm	STORES REAR MOTION	N		CIE132-Interior	
52	Alarm	BAY 1 MANDOOOR	N		CIE131-Perimeter	
53	Alarm	BAY 1 OHD	N		CIE131-Perimeter	
54	Alarm	BAY 1 MOTION	N		CIE132-Interior	
55	Alarm	SIGN SHOP/WOODSHOP RIGHT DOOR	N		CIE131-Perimeter	
56	Alarm	SIGN SHOP/WOODSHOP LEFT DOOR	N		CIE131-Perimeter	
57	Alarm	WOODSHOP TO HALLWAY DOOR	N		CIE131-Perimeter	
58	Alarm	SIGN SHOP OFFICE DOOR	N		CIE131-Perimeter	
59	Alarm	HALLWAY TO SIGN SHOP DOOR	N		CIE131-Perimeter	
60	Alarm	UPPER MEZZANINE LEFT DOOR	N		CIE131-Perimeter	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
61	Alarm	UPPER MEZZANINE RIGHT DOOR	N		CIE131-Perimeter	
62	Alarm	BAY 1 BACK STAIRWELL DOOR	N		CIE131-Perimeter	
65	Alarm		N		CIE110-FIRE ALARM - CALL PREM	
66	Alarm	Fire Trouble	N		CIE373-FIRE TROUBLE	
99	Alarm	WIRELESS PANIC	N		97-HOLD UP ALARM	
O/C	Armed		N		SE-05-LOG ONLY CLOSE	
O/C	Disarm		N		SE-04-LOG ONLY OPEN	
	1		N			
	1		N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 281290		System Type ANETG Alarmnet GSM Radio		Active Date 8/14/2009	
ATI Hours		Minutes		ATI Late Event#	
Alt ATI Hours		Minutes		ATI Global	
ATI Option				ATI Page	
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Event
					Equipment Type
1	Alarm	UCC Panic Button			79-PANIC - CALL PREM
				N	
2	Alarm	Lunch Room Panic Button			79-PANIC - CALL PREM
				N	
10	Alarm	FRONT ENTRY MOTION			CIE132-Interior
				N	
11	Alarm	FRONT ENTRY DOOR LEFT			CIE131-Perimeter
				N	
12	Alarm	FRONT ENTRY DOOR RIGHT			CIE131-Perimeter
				N	
13	Alarm	MEETING ROOM BY FRONT ENTRY MO			CIE132-Interior
				N	
14	Alarm	FRONT LOBBY MOTION			CIE132-Interior
				N	
15	Alarm	FRONT LOBBY STAIRWELL DOOR			CIE131-Perimeter
				N	
17	Alarm	RECEPTION TO OFFICE MOTION			CIE132-Interior
				N	
18	Alarm	MAIN FLOOR NORTH HALL EXIT DOOR			CIE131-Perimeter
				N	
19	Alarm	MAIN FLOOR NORTH EXIT MOTION			CIE132-Interior
				N	
20	Alarm	MAIN FLOOR SOUTH HALL DOOR			CIE131-Perimeter
				N	
21	Alarm	MAIN FLOOR HALL MOTION			CIE132-Interior
				N	
22	Alarm	CARPENTRY FRONT RIGHT MANDOOR			CIE131-Perimeter
				N	
23	Alarm	CARPENTRY FRONT RIGHT MOTION			CIE132-Interior
				N	
24	Alarm	CARPENTRY ROOF HATCH			CIE131-Perimeter
				N	
25	Alarm	CARPENTRY RIGHT OHD			CIE131-Perimeter
				N	
26	Alarm	SIGN SHOP EXIT DOOR			CIE131-Perimeter
				N	
27	Alarm	SIGN SHOP MOTION			CIE132-Interior
				N	
28	Alarm	SIGN SHOP OHD			CIE131-Perimeter
				N	
29	Alarm	CARPENTRY MOTION LEFT			CIE132-Interior
				N	
30	Alarm	CARPENTRY LEFT MANDOOR			CIE132-Interior
				N	
31	Alarm	CARPENTRY LEFT OHD			CIE131-Perimeter
				N	
32	Alarm	STORES MANDOOR ENTRY			CIE131-Perimeter
				N	
33	Alarm	STORES ENTRY MOTION			CIE132-Interior
				N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
34	Alarm	ELECTRICAL ROOM MOTION	N		CIE132-Interior	
35	Alarm	ELECTRICAL ROOM MANDOOOR	N		CIE131-Perimeter	
36	Alarm	SOUTH STAIRWELL TO STORES LOWEI	N		CIE132-Interior	
37	Alarm	NORTH STAIRWELL NORTH MOTION	N		CIE132-Interior	
38	Alarm	CAGE DOOR IN STORES BY ELECTRICI	N		CIE131-Perimeter	
39	Alarm	STORES DOOR BY SOUTH EXIT	N		CIE131-Perimeter	
40	Alarm	STORES DOOR BY ELEVATOR	N		CIE131-Perimeter	
41	Alarm	LOWER SOUTH EXIT DOOR LEFT	N		CIE131-Perimeter	
42	Alarm	LOWER SOUTH EXIT DOOR RIGHT	N		CIE131-Perimeter	
43	Alarm	SOUTH STAIRWELL TO BAYS LOWER M	N		CIE132-Interior	
44	Alarm	SOUTH STAIRWELL LOWER MOTION	N		CIE132-Interior	
45	Alarm	STORES OHD	N		CIE131-Perimeter	
46	Alarm	STORES MOTION BY OHD	N		CIE132-Interior	
47	Alarm	BAY 2 MANDOOOR LEFT	N		CIE131-Perimeter	
48	Alarm	BAY 2 MOTION	N		CIE132-Interior	
49	Alarm	BAY 2 MANDOOOR RIGHT	N		CIE131-Perimeter	
50	Alarm	BAY 2 OHD	N		CIE131-Perimeter	
51	Alarm	STORES REAR MOTION	N		CIE132-Interior	
52	Alarm	BAY 1 MANDOOOR	N		CIE131-Perimeter	
53	Alarm	BAY 1 OHD	N		CIE131-Perimeter	
54	Alarm	BAY 1 MOTION	N		CIE132-Interior	
55	Alarm	SIGN SHOP/WOODSHOP RIGHT DOOR	N		CIE131-Perimeter	
56	Alarm	SIGN SHOP/WOODSHOP LEFT DOOR	N		CIE131-Perimeter	
57	Alarm	WOODSHOP TO HALLWAY DOOR	N		CIE131-Perimeter	
58	Alarm	SIGN SHOP OFFICE DOOR	N		CIE131-Perimeter	
59	Alarm	HALLWAY TO SIGN SHOP DOOR	N		CIE131-Perimeter	
60	Alarm	UPPER MEZZANINE LEFT DOOR	N		CIE131-Perimeter	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
61	Alarm	UPPER MEZZANINE RIGHT DOOR	N		CIE131-Perimeter	
62	Alarm	BAY 1 BACK STAIRWELL DOOR	N		CIE131-Perimeter	
65	Alarm		N		CIE110-FIRE ALARM - CALL PREM	
66	Alarm		N		CIE373-FIRE TROUBLE	
99	Alarm	Wireless Panic	N		79-PANIC - CALL PREM	

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000071	CITY OF COQUITLAM 500 MARINER WAY VEHICLE SERVICE BUILDING COQUITLAM, BC V3K 6C4	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company 3511-COQUITLAM COMMERCIAL		Corporate Account 2026-CITY OF COQUITLAM		Service Company 3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Contact Name	CS Seq	Contact Type	Relation	Call List	
Contact#	Authoritv	Kevs? PIN		Site Dates	Verifv?

Gen Dispatch	Permanent	Effective Date	8/19/2009 00:00	Expire Date	
CALL ALL BBS BEFORE DISPATCHING BB CALL					

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 223076		System Type FA168 First Alert 168			
ATI Hours 26		Minutes		ATI Late Event# G-NOTT	
Alt ATI Hours		Minutes		Active Date 10/1/2009	
ATI Option				ATI Global	
				ATI Page	
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Event
					Equipment Type
1	Alarm	Fire Alarm			CIE110-FIRE ALARM - CALL PREM
				N	
2	Trouble	Fire Trouble			CIE373-FIRE TROUBLE
				N	
10	Alarm	LIGHT DUTY SOUTH MANDOOR			CIE131-Perimeter
				N	
11	Alarm	LIGHT DUTY SOUTH MOTION			CIE132-Interior
				N	
12	Alarm	LIGHT DUTY SOUTH OHD			CIE131-Perimeter
				N	
13	Alarm	LIGHT DUTY EASTSIDE RIGHT MOTION			CIE132-Interior
				N	
14	Alarm	LIGHT DUTY EASTSIDE LEFT MOTION			CIE132-Interior
				N	
15	Alarm	LIGHT DUTY EASTSIDE RIGHT OHD			CIE131-Perimeter
				N	
16	Alarm	LIGHT DUTY EASTSIDE LEFT OHD			CIE131-Perimeter
				N	
17	Alarm	LIGHT DUTY NORTH MOTION			CIE132-Interior
				N	
18	Alarm	LIGHT DUTY NORTH MANDOOR			CIE131-Perimeter
				N	
19	Alarm	LIGHT DUTY NORTH OHD			CIE131-Perimeter
				N	
20	Alarm	LIGHT DUTY WEST OHD			CIE131-Perimeter
				N	
21	Alarm	LIGHT DUTY WEST MANDOOR			CIE131-Perimeter
				N	
22	Alarm	LIGHT DUTY NORTH WEST MOTION			CIE132-Interior
				N	
23	Alarm	LIGHT DUTY WEST MOTION			CIE132-Interior
				N	
24	Alarm	LIGHT DUTY WEST MANDOOR TO HALL			CIE131-Perimeter
				N	
25	Alarm	LIGHT DUTY SOUTHWEST MANDOOR T			CIE131-Perimeter
				N	
26	Alarm	LIGHT DUTY EAST MANDOOR			CIE131-Perimeter
				N	
27	Alarm	GARAGE OFFICE DOOR			CIE131-Perimeter
				N	
28	Alarm	GARAGE OFFICE MOTION			CIE132-Interior
				N	
29	Alarm	SMALL MOTORS SHOP TO HALL, LEFT I			CIE131-Perimeter
				N	
30	Alarm	SMALL MOTORS SHOP TO HALL, RIGHT			CIE131-Perimeter
				N	
31	Alarm	SMALL MOTORS OHD			CIE131-Perimeter
				N	
32	Alarm	SMALL MOTORS MANDOOR			CIE131-Perimeter
				N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
33	Alarm	SMALL MOTORS MANDOOR			CIE131-Perimeter	
			N			
34	Alarm	PAINT SHOP MANDOOR			CIE131-Perimeter	
			N			
35	Alarm	PAINT SHOP MOTION			CIE132-Interior	
			N			
36	Alarm	PAINT SHOP OHD			CIE131-Perimeter	
			N			
37	Alarm	HEAVY DUTY SHOP NORTH RIGHT OH			CIE131-Perimeter	
			N			
38	Alarm	HEAVY DUTY SHOP NORTH LEFT OH			CIE131-Perimeter	
			N			
39	Alarm	HEAVY DUTY SHOP NORTH LEFT OH			CIE131-Perimeter	
			N			
40	Alarm	HEAVY DUTY SHOP NORTH MOTION			CIE132-Interior	
			N			
41	Alarm	WELDING SHOP MOTION			CIE132-Interior	
			N			
42	Alarm	WELDING SHOP OH			CIE131-Perimeter	
			N			
43	Alarm	WELDING SHOP MANDOOR			CIE131-Perimeter	
			N			
44	Alarm	HEAVY DUTY SHOP WEST ROLL UP GA			CIE131-Perimeter	
			N			
45	Alarm	HEAVY DUTY SHOP WEST MANDOOR			CIE131-Perimeter	
			N			
46	Alarm	HEAVY DUTY SHOP SOUTH RIGHT OH			CIE131-Perimeter	
			N			
47	Alarm	HEAVY DUTY SHOP SOUTH LEFT OH			CIE131-Perimeter	
			N			
48	Alarm	HEAVY DUTY SHOP SOUTH MANDOOR			CIE131-Perimeter	
			N			
49	Alarm	HEAVY DUTY SHOP SOUTH MOTION			CIE132-Interior	
			N			
50	Alarm	VEHICLE SERVICES FRONT ENTRY RIG			CIE131-Perimeter	
			N			
51	Alarm	VEHICLE SERVICES FRONT ENTRY LEF			CIE131-Perimeter	
			N			
52	Alarm	VEHICLE SERVICES FRONT ENTRY MO			CIE132-Interior	
			N			
53	Alarm	SOUTH STAIRWELL EXIT DOOR			CIE131-Perimeter	
			N			
54	Alarm	SOUTH STAIRWELL MOTION			CIE132-Interior	
			N			
55	Alarm	TRAFFIC STORAGE TO LIGHT DUTY RIC			CIE131-Perimeter	
			N			
56	Alarm	TRAFFIC STORAGE TO LIGHT DUTY LEI			CIE131-Perimeter	
			N			
57	Alarm	TRAFFIC STORAGE MOTION			CIE132-Interior	
			N			
58	Alarm	TRAFFIC STORAGE OH			CIE131-Perimeter	
			N			
59	Alarm	TRAFFIC STORAGE NORTH MANDOOR			CIE131-Perimeter	
			N			

Installer# First to Last			CS# First to Last			Corporate Account 2026		
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
60	Alarm	VEHICLE SERVICES LOBBY TO TRAFFIC	N		CIE131-Perimeter			
61	Alarm	TRAFFIC OFFICE WEST MOTION	N		CIE132-Interior			
62	Alarm	TRAFFIC OFFICE EAST MOTION	N		CIE132-Interior			
63	Alarm	TRAFFIC OFFICE TO HALL	N		CIE131-Perimeter			
64	Alarm	TRAFFIC SIGNAL OFFICE DOOR	N		CIE131-Perimeter			
65	Alarm	TRAFFIC SIGNAL OFFICE MOTION	N		CIE132-Interior			
66	Alarm	TOOL CRIB DOOR	N		CIE131-Perimeter			
67	Alarm	TOOL CRIB MOTION	N		CIE132-Interior			
O/C	Armed		N		SE-05-LOG ONLY CLOSE			
	1		N					
O/C	Disarm		N		SE-04-LOG ONLY OPEN			
	1		N					

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 281291		System Type ANETG Alarmnet GSM Radio		Active Date 8/14/2009	
ATI Hours	Minutes	ATI Late Event#			
Alt ATI Hours	Minutes	ATI Global			
ATI Option		ATI Page			
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm				CIE110-FIRE ALARM - CALL PREM
				N	
2	Alarm				CIE373-FIRE TROUBLE
				N	
10	Alarm	LIGHT DUTY SOUTH MANDOOR			CIE131-Perimeter
				N	
11	Alarm	LIGHT DUTY SOUTH MOTION			CIE132-Interior
				N	
12	Alarm	LIGHT DUTY SOUTH OHD			CIE131-Perimeter
				N	
13	Alarm	LIGHT DUTY EASTSIDE RIGHT MOTION			CIE132-Interior
				N	
14	Alarm	LIGHT DUTY EASTSIDE LEFT MOTION			CIE132-Interior
				N	
15	Alarm	LIGHT DUTY EASTSIDE RIGHT OHD			CIE131-Perimeter
				N	
16	Alarm	LIGHT DUTY EASTSIDE LEFT OHD			CIE131-Perimeter
				N	
17	Alarm	LIGHT DUTY NORTH MOTION			CIE132-Interior
				N	
18	Alarm	LIGHT DUTY NORTH MANDOOR			CIE131-Perimeter
				N	
19	Alarm	LIGHT DUTY NORTH OHD			CIE131-Perimeter
				N	
20	Alarm	LIGHT DUTY WEST OHD			CIE131-Perimeter
				N	
21	Alarm	LIGHT DUTY WEST MANDOOR			CIE131-Perimeter
				N	
22	Alarm	LIGHT DUTY NORTH WEST MOTION			CIE132-Interior
				N	
23	Alarm	LIGHT DUTY WEST MOTION			CIE132-Interior
				N	
24	Alarm	LIGHT DUTY WEST MANDOOR TO HALL			CIE131-Perimeter
				N	
25	Alarm	LIGHT DUTY SOUTHWEST MANDOOR T			CIE131-Perimeter
				N	
26	Alarm	LIGHT DUTY EAST MANDOOR			CIE131-Perimeter
				N	
27	Alarm	GARAGE OFFICE DOOR			CIE131-Perimeter
				N	
28	Alarm	GARAGE OFFICE MOTION			CIE132-Interior
				N	
29	Alarm	SMALL MOTORS SHOP TO HALL, LEFT I			CIE131-Perimeter
				N	
30	Alarm	SMALL MOTORS SHOP TO HALL, RIGHT			CIE131-Perimeter
				N	
31	Alarm	SMALL MOTORS OHD			CIE131-Perimeter
				N	
32	Alarm	SMALL MOTORS MANDOOR			CIE131-Perimeter
				N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
33	Alarm	SMALL MOTORS MANDOOR			CIE131-Perimeter	
			N			
34	Alarm	PAINT SHOP MANDOOR			CIE131-Perimeter	
			N			
35	Alarm	PAINT SHOP MOTION			CIE132-Interior	
			N			
36	Alarm	PAINT SHOP OHD			CIE131-Perimeter	
			N			
37	Alarm	HEAVY DUTY SHOP NORTH RIGHT OHD			CIE131-Perimeter	
			N			
38	Alarm	HEAVY DUTY SHOP NORTH LEFT OHD			CIE131-Perimeter	
			N			
39	Alarm	HEAVY DUTY SHOP NORTH LEFT OHD			CIE131-Perimeter	
			N			
40	Alarm	HEAVY DUTY SHOP NORTH MOTION			CIE132-Interior	
			N			
41	Alarm	WELDING SHOP MOTION			CIE132-Interior	
			N			
42	Alarm	WELDING SHOP OHD			CIE131-Perimeter	
			N			
43	Alarm	WELDING SHOP MANDOOR			CIE131-Perimeter	
			N			
44	Alarm	HEAVY DUTY SHOP WEST ROLL UP GA			CIE131-Perimeter	
			N			
45	Alarm	HEAVY DUTY SHOP WEST MANDOOR			CIE131-Perimeter	
			N			
46	Alarm	HEAVY DUTY SHOP SOUTH RIGHT OHD			CIE131-Perimeter	
			N			
47	Alarm	HEAVY DUTY SHOP SOUTH LEFT OHD			CIE131-Perimeter	
			N			
48	Alarm	HEAVY DUTY SHOP SOUTH MANDOOR			CIE131-Perimeter	
			N			
49	Alarm	HEAVY DUTY SHOP SOUTH MOTION			CIE132-Interior	
			N			
50	Alarm	VEHICLE SERVICES FRONT ENTRY RIC			CIE131-Perimeter	
			N			
51	Alarm	VEHICLE SERVICES FRONT ENTRY LEF			CIE131-Perimeter	
			N			
52	Alarm	VEHICLE SERVICES FRONT ENTRY MO			CIE132-Interior	
			N			
53	Alarm	SOUTH STAIRWELL EXIT DOOR			CIE131-Perimeter	
			N			
54	Alarm	SOUTH STAIRWELL MOTION			CIE132-Interior	
			N			
55	Alarm	TRAFFIC STORAGE TO LIGHT DUTY RIC			CIE131-Perimeter	
			N			
56	Alarm	TRAFFIC STORAGE TO LIGHT DUTY LEI			CIE131-Perimeter	
			N			
57	Alarm	TRAFFIC STORAGE MOTION			CIE132-Interior	
			N			
58	Alarm	TRAFFIC STORAGE OHD			CIE131-Perimeter	
			N			
59	Alarm	TRAFFIC STORAGE NORTH MANDOOR			CIE131-Perimeter	
			N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type
60	Alarm	VEHICLE SERVICES LOBBY TO TRAFFIC	N		CIE131-Perimeter
61	Alarm	TRAFFIC OFFICE WEST MOTION	N		CIE132-Interior
62	Alarm	TRAFFIC OFFICE EAST MOTION	N		CIE132-Interior
63	Alarm	TRAFFIC OFFICE TO HALL	N		CIE131-Perimeter
64	Alarm	TRAFFIC SIGNAL OFFICE DOOR	N		CIE131-Perimeter
65	Alarm	TRAFFIC SIGNAL OFFICE MOTION	N		CIE132-Interior
66	Alarm	TOOL CRIB DOOR	N		CIE131-Perimeter
67	Alarm	TOOL CRIB MOTION	N		CIE132-Interior
68	Alarm	SECURITY DOOR A1	N		CIE131-Perimeter
69	Alarm	SECURITY DOOR A2	N		CIE131-Perimeter
70	Alarm	INSPECTION DOOR A3	N		CIE131-Perimeter
71	Alarm	SURVEY DOOR A4	N		CIE131-Perimeter
72	Alarm	PARKS DOOR A5	N		CIE131-Perimeter
73	Alarm	PARKS DOOR A6	N		CIE131-Perimeter
74	Alarm	SECURITY ROOM A1 MOTION	N		CIE132-Interior
75	Alarm	SECURITY ROOM A2 MOTION	N		CIE132-Interior
76	Alarm	INSPECTION DEPARTMENT MOTION	N		CIE132-Interior
77	Alarm	INSPECTION DEPARTMENT SIDE OFFIC	N		CIE132-Interior
78	Alarm	SURVEY DEPARTMENT MOTION	N		CIE132-Interior
79	Alarm	KITCHEN AREA MOTION	N		CIE132-Interior
80	Alarm	PARKS A5 MOTION	N		CIE132-Interior
81	Alarm	PARKS A6 MOTION	N		CIE132-Interior
82	Alarm	PARKS BACK OFFICE MOTION	N		CIE132-Interior
O/C	Armed		N		SE-05-LOG ONLY CLOSE
	1		N		
O/C	Disarm		N		SE-04-LOG ONLY OPEN
	1		N		

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000075	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	620 POIRIER STREET	Yes		Active	
	CENTENNIAL PAVILLION	Cross Street			
	COQUITLAM, BC V3J 6B1	Codewords			
604-927-6300	604-927-6095	Corporate Account		2026-CITY OF COQUITLAM	
Installing Company 3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 220152		System Type V128 Vista 128		Active Date 8/20/2009	
ATI Hours	Minutes	ATI Late Event#			
Alt ATI Hours	Minutes	ATI Global			
ATI Option		ATI Page			
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm				CIE110-FIRE ALARM - CALL PREM
				Y	
1	Trouble				CIE373-FIRE TROUBLE
				Y	
2	Alarm				CIE373-FIRE TROUBLE
				Y	
2	Trouble				CIE373-FIRE TROUBLE
				Y	
3	Alarm				CIE200-FIRE SUPERVISORY Alert
				Y	
3	Trouble				CIE373-FIRE TROUBLE
				Y	
4	Alarm	Left Entry Door			CIE134-Entry/Exit
				N	
5	Alarm	Right Entry Door			CIE134-Entry/Exit
				N	
6	Alarm	Lobby, Right Side, Left Door			CIE131-Perimeter
				N	
7	Alarm	Lobby, Right Side, Right Door			CIE131-Perimeter
				N	
8	Alarm	Lobby, Left Side Door			CIE134-Entry/Exit
				N	
9	Alarm	Lobby, Right Side Door			CIE131-Perimeter
				N	
17	Alarm	Lobby, Back Left Door			CIE131-Perimeter
				N	
18	Alarm	Lobby, Back Right Door			CIE131-Perimeter
				N	
19	Alarm	Lobby Motion			CIE132-Interior
				N	
20	Alarm	Room 102 Motion			CIE132-Interior
				N	
21	Alarm	Centennial Room, Front Motion			CIE132-Interior
				N	
22	Alarm	Centennial Room, Front Left Door			CIE131-Perimeter
				N	
23	Alarm	Centennial Room, Front Right Door			CIE131-Perimeter
				N	
24	Alarm	Centennial Room, Back Motion			CIE132-Interior
				N	
25	Alarm	Centennial Room, Left Doors, Left Door			CIE131-Perimeter
				N	
26	Alarm	Centennial Room, Left Doors, Right Doors			CIE131-Perimeter
				N	
27	Alarm	Centennial Room, Right Doors, Left Door			CIE131-Perimeter
				N	
28	Alarm	Centennial Room, Right Doors, Right Door			CIE131-Perimeter
				N	
29	Alarm	Kitchen Door			CIE131-Perimeter
				N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
30	Alarm	Kitchen Motion			CIE132-Interior	
			N			
31	Alarm	Panel Room Motion			CIE132-Interior	
			N			
32	Alarm	Electrical Room Door			CIE131-Perimeter	
			N			
O/C	Armed				SE-05-LOG ONLY CLOSE	
	1		N			
O/C	Disarm				SE-04-LOG ONLY OPEN	
	1		N			

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 281293		System Type ANETG Alarmnet GSM Radio			
ATI Hours 26		Minutes		ATI Late Event# G-NOTT	
Alt ATI Hours		Minutes		Active Date 8/20/2009	
ATI Option		ATI Global		ATI Page	
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm				33-FIRE - DISPATCH 1ST
				Y	
1	Trouble				CIE373-FIRE TROUBLE
				Y	
2	Alarm				CIE373-FIRE TROUBLE
				Y	
2	Trouble				CIE373-FIRE TROUBLE
				Y	
3	Alarm				CIE200-FIRE SUPERVISORY Alert
				N	
3	Trouble				CIE373-FIRE TROUBLE
				N	
4	Alarm	Left Entry Door			CIE134-Entry/Exit
				N	
5	Alarm	Right Entry Door			CIE134-Entry/Exit
				N	
6	Alarm	Lobby, Right Side, Left Door			CIE131-Perimeter
				N	
7	Alarm	Lobby, Right Side, Right Door			CIE131-Perimeter
				N	
8	Alarm	Lobby, Left Side Door			CIE131-Perimeter
				N	
9	Alarm	Lobby, Right Side Door			CIE131-Perimeter
				N	
17	Alarm	Lobby, Back Left Door			CIE131-Perimeter
				N	
18	Alarm	Lobby, Back Right Door			CIE131-Perimeter
				N	
19	Alarm	Lobby Motion			CIE132-Interior
				N	
20	Alarm	Room 102 Motion			CIE132-Interior
				N	
21	Alarm	Centennial Room, Front Motion			CIE132-Interior
				N	
22	Alarm	Centennial Room, Front Left Door			CIE131-Perimeter
				N	
23	Alarm	Centennial Room, Front Right Door			CIE131-Perimeter
				N	
24	Alarm	Centennial Room, Back Motion			CIE132-Interior
				N	
25	Alarm	Centennial Room, Left Doors, Left Door			CIE131-Perimeter
				N	
26	Alarm	Centennial Room, Left Doors, Right Doors			CIE131-Perimeter
				N	
27	Alarm	Centennial Room, Right Doors, Left Door			CIE131-Perimeter
				N	
28	Alarm	Centennial Room, Right Doors, Right Door			CIE131-Perimeter
				N	
29	Alarm	Kitchen Door			CIE131-Perimeter
				N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
30	Alarm	Kitchen Motion			CIE132-Interior	
			N			
31	Alarm	Panel Room Motion			CIE132-Interior	
			N			
32	Alarm	Electrical Room Door			CIE131-Perimeter	
			N			
O/C	Armed				SE-05-LOG ONLY CLOSE	
	1		N			
O/C	Disarm				SE-04-LOG ONLY OPEN	
	1		N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000076	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	500 MARINER WAY	Yes		Active	
	ANIMAL SHELTER	Cross Street			
	COQUITLAM, BC V3K 7B6	Codewords			
	604-927-7386	604-927-7385	Corporate Account	2026-CITY OF COQUITLAM	
	Installing Company	3511-COQUITLAM COMMERCIAL	Service Company	3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 220146			System Type V128 Vista 128					
ATI Hours 26 Minutes			ATI Late Event# G-NOTT			Active Date 9/21/2009		
Alt ATI Hours Minutes			ATI Global					
ATI Option 2-Timer Test Only			ATI Page					
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
1	Alarm	Front Door			CIE134-Entry/Exit			
			N					
2	Alarm	Upstairs Motion			CIE132-Interior			
			N					
3	Alarm	Front Motion			CIE132-Interior			
			N					
4	Alarm	Back Motion			CIE132-Interior			
			N					
5	Alarm	Back Door			CIE131-Perimeter			
			N					
6	Alarm	Cat Room Door			CIE131-Perimeter			
			N					
7	Alarm	Cooler Room Door			CIE131-Perimeter			
			N					
8	Alarm	Back Door East			CIE131-Perimeter			
			N					
9	Alarm	Impound Door Front			CIE131-Perimeter			
			N					
17	Alarm	Impound Door Back			CIE131-Perimeter			
			N					
18	Alarm	Kennel Front Door			CIE131-Perimeter			
			N					
19	Alarm	Kennel Back Door			CIE131-Perimeter			
			N					
20	Alarm	Adoption Front Door			CIE131-Perimeter			
			N					
21	Alarm	Adoption Back Door			CIE131-Perimeter			
			N					
22	Alarm				CIE110-FIRE ALARM - CALL PREM			
			Y					
22	Trouble				CIE373-FIRE TROUBLE			
			Y					
23	Alarm				CIE200-FIRE SUPERVISORY Alert			
			Y					
23	Trouble				CIE200-FIRE SUPERVISORY Alert			
			Y					
25	Alarm	HOLD UP			97-HOLD UP ALARM			
			N					
O/C	Armed				SE-03-SCHEDULED CLOSE			
	1		N					
O/C	Disarm				SE-02-SCHEDULED OPEN			
	1		N					

Installer# First to Last

CS# First to Last

Corporate Account 2026

CS# 220146			Schedule# 1			Effective 9/15/2016			Expires			
Comment									One Open? N		One Irregular Open? N	
Early Open Window 30			Alarm? Y	Page		Late Open Window 30			Alarm? N	Page		
Early Close Window 30			Alarm? N	Page		Late Close Window 30			Alarm? N	Page		
Fail to Open Event			Page		Fail to Close Event FAIL			Page				
Day Of Week	Open1	Close1	Open2	Close2	Open3	Close3	Open4	Close4	Open5	Close5	Open6	Close6
Sunday	07:00	20:30										
Monday	07:00	21:30										
Tuesday	07:00	21:30										
Wednesday	07:00	21:30										
Thursday	07:00	21:30										
Friday	07:00	21:30										
Saturday	07:00	20:30										

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 281298		System Type ANETG Alarmnet GSM Radio		Active Date 9/21/2009	
ATI Hours		Minutes		ATI Late Event#	
Alt ATI Hours		Minutes		ATI Global	
ATI Option				ATI Page	
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm	Front Door			CIE134-Entry/Exit
				N	
2	Alarm	Upstairs Motion			CIE132-Interior
				N	
3	Alarm	Front Motion			CIE132-Interior
				N	
4	Alarm	Back Motion			CIE132-Interior
				N	
5	Alarm	Back Door			CIE131-Perimeter
				N	
6	Alarm	Cat Room Door			CIE131-Perimeter
				N	
7	Alarm	Cooler Room Door			CIE131-Perimeter
				N	
8	Alarm	Back Door East			CIE131-Perimeter
				N	
9	Alarm	Impound Door Front			CIE131-Perimeter
				N	
17	Alarm	Impound Door Back			CIE131-Perimeter
				N	
18	Alarm	Kennel Front Door			CIE131-Perimeter
				N	
19	Alarm	Kennel Back Door			CIE131-Perimeter
				N	
20	Alarm	Adoption Front Door			CIE131-Perimeter
				N	
21	Alarm	Adoption Back Door			CIE131-Perimeter
				N	
22	Alarm				CIE110-FIRE ALARM - CALL PREM
				N	
22	Trouble				CIE373-FIRE TROUBLE
				N	
23	Alarm				CIE200-FIRE SUPERVISORY Alert
				N	
23	Trouble				CIE200-FIRE SUPERVISORY Alert
				N	
25	Alarm	HOLD UP			97-HOLD UP ALARM
				N	
E341				Y	
O/C	Armed				SE-03-SCHEDULED CLOSE
	1			N	
O/C	Disarm				SE-02-SCHEDULED OPEN
	1			N	

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000077	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	621 ROBINSON STREET	Yes		Active	
	ROBINSON CEMETERY ADMIN	Cross Street			
	COQUITLAM, BC V3J 0A6	Codewords			
	604-927-6020	604-617-9120	Corporate Account	2026-CITY OF COQUITLAM	
	Installing Company	3511-COQUITLAM COMMERCIAL	Service Company	3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 221914			System Type V128 Vista 128					
ATI Hours 26 Minutes			ATI Late Event# G-NOTT			Active Date 10/5/2009		
Alt ATI Hours			Minutes					
ATI Option			ATI Global					
			ATI Page					
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
1	Alarm	Front Door			CIE134-Entry/Exit			
			N					
2	Alarm	Kitchen Door			CIE131-Perimeter			
			N					
3	Alarm	Downstairs Door			CIE131-Perimeter			
			N					
4	Alarm	Downstairs Overhead Door			CIE131-Perimeter			
			N					
5	Alarm	Office Front Window			CIE131-Perimeter			
			N					
6	Alarm	Office Back Window			CIE131-Perimeter			
			N					
7	Alarm	Office Door			CIE131-Perimeter			
			N					
8	Alarm	Kitchen Motion			CIE132-Interior			
			N					
9	Alarm	Office Motion			CIE132-Interior			
			N					
10	Alarm	Kitchen Entry Door			CIE134-Entry/Exit			
			N					
11	Alarm	Front Door			CIE134-Entry/Exit			
			N					
12	Alarm	Rear Office Window			CIE131-Perimeter			
			N					
13	Alarm	Kitchen Motion			CIE132-Interior			
			N					
14	Alarm	Front Entry Motion			CIE131-Perimeter			
			N					
15	Alarm	Office Motion			CIE132-Interior			
			N					
16	Alarm	Janitors Window and Door			CIE131-Perimeter			
			N					
O/C	Armed				SE-05-LOG ONLY CLOSE			
	1		N					
O/C	Disarm				SE-04-LOG ONLY OPEN			
	1		N					

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 281033		System Type ANETG Alarmnet GSM Radio		Active Date 10/5/2009	
ATI Hours		Minutes			
Alt ATI Hours		Minutes			
ATI Option		ATI Global			
ATI Page					
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm	Front Door			CIE134-Entry/Exit
				N	
2	Alarm	Kitchen Door			CIE131-Perimeter
				N	
3	Alarm	Downstairs Door			CIE131-Perimeter
				N	
4	Alarm	Downstairs Overhead Door			CIE131-Perimeter
				N	
5	Alarm	Office Front Window			CIE131-Perimeter
				N	
6	Alarm	Office Back Window			CIE131-Perimeter
				N	
7	Alarm	Office Door			CIE131-Perimeter
				N	
8	Alarm	Kitchen Motion			CIE132-Interior
				N	
9	Alarm	Office Motion			CIE132-Interior
				N	
10	Alarm	Kitchen Entry Door			CIE134-Entry/Exit
				N	
11	Alarm	Front Door			CIE134-Entry/Exit
				N	
12	Alarm	Rear Office Window			CIE131-Perimeter
				N	
13	Alarm	Kitchen Motion			CIE132-Interior
				N	
14	Alarm	Front Entry Motion			CIE132-Interior
				N	
15	Alarm	Office Motion			CIE132-Interior
				N	
16	Alarm	Janitors Door and Window			CIE131-Perimeter
				N	
O/C	Armed				SE-05-LOG ONLY CLOSE
	1			N	
O/C	Disarm				SE-04-LOG ONLY OPEN
	1			N	

Installer# First to Last	CS# First to Last	Corporate Account 2026
Site# Site Name & Address	Time Zone/Daylight Savings	Site Type/Status
10000080 CITY OF COQUITLAM	Pacific Time Zone	ULC Account
1200 GLEN PINE COURT	Yes	Active
GLEN PINE PAVILION	Cross Street	
COQUITLAM, BC V3B 2P7	Codewords	
604-927-6068	Corporate Account	2026-CITY OF COQUITLAM
Installing Company 3811-COQUITLAM ULC ACCOUNT	Service Company	3811-COQUITLAM ULC ACCOUNT
Agency#-Name/Comment Address	Type Phone 1	Phone 2
10-COQUITLAM PD	P 604-464-6211	
71-COQUITLAM FD	F 604-215-4826	

Gen Dispatch Permanent **Effective Date** 12/13/2021 11:56 **Expire Date**
 NO DISPATCH INSTALL PENDING

CS# 22F248 **System Type** WINC Radio Communicator

ATI Hours	Minutes	ATI Late Event#	Active Date
Alt ATI Hours	Minutes	ATI Global	
ATI Option		ATI Page	

CS# 11F248 **System Type** WINC Radio Communicator

ATI Hours	26	Minutes	ATI Late Event# W-NOTT	Active Date
Alt ATI Hours		Minutes	ATI Global	
ATI Option			ATI Page	

CS# 12F248 **System Type** WINC Radio Communicator

ATI Hours	6	Minutes	ATI Late Event# W-NOTT	Active Date
Alt ATI Hours		Minutes	ATI Global	
ATI Option			ATI Page	

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000085	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	640 POIRIER STREET	Yes		Active	
	POIRIER ADMIN BUILDING	Cross Street			
	COQUITLAM, BC V6J 6B1	Codewords			
	604-927-6300	Corporate Account		2026-CITY OF COQUITLAM	
	Installing Company 3511-COQUITLAM COMMERCIAL	Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 223087		System Type V128 Vista 128			
ATI Hours 26		Minutes		ATI Late Event# G-NOTT	
Alt ATI Hours		Minutes		Active Date 7/28/2010	
ATI Option				ATI Global	
				ATI Page	
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Event
					Equipment Type
1	Alarm	4 Smoke Detectors			CIE110-FIRE ALARM - CALL PREM
				N	
2	Alarm	Lower Entry Door			CIE134-Entry/Exit
				N	
3	Alarm	Office # 3 Window			CIE131-Perimeter
				N	
4	Alarm	Office # 4 Window			CIE131-Perimeter
				N	
5	Alarm	Office # 5 Window			CIE131-Perimeter
				N	
6	Alarm	Office # 6 Window			CIE131-Perimeter
				N	
7	Alarm	Office # 7 Window			CIE131-Perimeter
				N	
8	Alarm	Office # 8 Window			CIE131-Perimeter
				N	
9	Alarm	Office # 9 Window			CIE131-Perimeter
				N	
17	Alarm	Lunch Room Window			CIE131-Perimeter
				N	
18	Alarm	Furnace Exterior Door			CIE131-Perimeter
				N	
19	Alarm	Window In Furnace Room			CIE131-Perimeter
				N	
20	Alarm	Office # 3 Motion			CIE132-Interior
				N	
21	Alarm	Office # 4 Motion			CIE132-Interior
				N	
22	Alarm	Office # 5 Motion			CIE132-Interior
				N	
23	Alarm	Office # 6 Motion			CIE132-Interior
				N	
24	Alarm	Hallway Entry Motion			CIE132-Interior
				N	
25	Alarm	Office # 7 Motion			CIE132-Interior
				N	
26	Alarm	Office # 8 Motion			CIE132-Interior
				N	
27	Alarm	Office # 9 Motion			CIE132-Interior
				N	
28	Alarm	Lunch Room Motion			CIE132-Interior
				N	
29	Alarm	Upstairs Entry Door			CIE134-Entry/Exit
				N	
30	Alarm	Upstairs Entry Motion			CIE132-Interior
				N	
31	Alarm	Meeting Room Motion			CIE132-Interior
				N	
32	Alarm	Office # 11 Window			CIE131-Perimeter
				N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
33	Alarm	Office # 12 Window			CIE131-Perimeter	
			N			
34	Alarm	Office # 13 Window			CIE131-Perimeter	
			N			
35	Alarm	Office # 14 Window			CIE131-Perimeter	
			N			
36	Alarm	Office # 15 Window			CIE131-Perimeter	
			N			
37	Alarm	Office # 16 Window			CIE131-Perimeter	
			N			
38	Alarm	Office # 17 Window			CIE131-Perimeter	
			N			
39	Alarm	Office # 20 Motion			CIE132-Interior	
			N			
40	Alarm	Office # 21 Motion (Lunch Room)			CIE132-Interior	
			N			
41	Alarm	Office # 18 Window			CIE131-Perimeter	
			N			
42	Alarm	Office # 19 Window			CIE131-Perimeter	
			N			
43	Alarm	Office # 20 Window			CIE131-Perimeter	
			N			
44	Alarm	Office # 21 Window (Lunch Room)			CIE131-Perimeter	
			N			
45	Alarm	Storage Room Window			CIE131-Perimeter	
			N			
46	Alarm	Storage Room Motion			CIE132-Interior	
			N			
47	Alarm	Office # 11 Motion			CIE132-Interior	
			N			
48	Alarm	Office # 12 Motion			CIE132-Interior	
			N			
49	Alarm	Office # 13 Motion			CIE132-Interior	
			N			
50	Alarm	Office # 14 Motion			CIE132-Interior	
			N			
51	Alarm	Office # 15 Motion			CIE132-Interior	
			N			
52	Alarm	Office # 16 Motion			CIE132-Interior	
			N			
53	Alarm	Office # 17 Motion			CIE132-Interior	
			N			
54	Alarm	Office # 18 Motion			CIE132-Interior	
			N			
55	Alarm	Office # 19 Motion			CIE132-Interior	
			N			
56	Alarm	Office # 23 Motion			CIE132-Interior	
			N			
57	Alarm	Office # 22 Motion			CIE132-Interior	
			N			
58	Alarm	North Hall Motion			CIE132-Interior	
			N			
59	Alarm	South East Second Floor Fire Door			CIE131-Perimeter	
			N			

Installer# First to Last			CS# First to Last			Corporate Account 2026		
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
60	Alarm	Computer Room Temperature Alarm			CIE150-Alarm (24-hour non-burglary)			
			Y					
O/C	Armed				SE-05-LOG ONLY CLOSE			
	1		N					
O/C	Disarm				SE-04-LOG ONLY OPEN			
	1		N					

Installer# First to Last

CS# First to Last

Corporate Account 2026

CS# 113087 System Type WINC Radio Communicator

ATI Hours 24 Minutes 15 ATI Late Event# W-NOTT Active Date 7/28/2010

Alt ATI Hours Minutes ATI Global

ATI Option 2-Timer Test Only ATI Page

Zone	State	Location/Comment	Page	GL Page	Event
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type
1	Alarm	Siren Trip	Y		151-BURGLAR ALARM
1	Trouble	Siren Trip	Y		850-TROUBLE

Installer# First to Last			CS# First to Last		Corporate Account 2026	
CS# 133087		System Type WINC Radio Communicator				
ATI Hours		Minutes		ATI Late Event#		Active Date 7/28/2010
Alt ATI Hours		Minutes		ATI Global		
ATI Option				ATI Page		
Zone	State	Location/Comment			Page	GL Page Event
GL Sch	Sch#	Alarm Group			Restore?	Equipment Type
1	Alarm	4 Smoke Detectors				CIE110-FIRE ALARM - CALL PREM
					N	
2	Alarm	Lower Entry Door				CIE134-Entry/Exit
					N	
3	Alarm	Office # 3 Window				CIE131-Perimeter
					N	
4	Alarm	Office # 4 Window				CIE131-Perimeter
					N	
5	Alarm	Office # 5 Window				CIE131-Perimeter
					N	
6	Alarm	Office # 6 Window				CIE131-Perimeter
					N	
7	Alarm	Office # 7 Window				CIE131-Perimeter
					N	
8	Alarm	Office # 8 Window				CIE131-Perimeter
					N	
9	Alarm	Office # 9 Window				CIE131-Perimeter
					N	
17	Alarm	Lunch Room Window				CIE131-Perimeter
					N	
18	Alarm	Furnace Exterior Door				CIE131-Perimeter
					N	
19	Alarm	Window In Furnace Room				CIE131-Perimeter
					N	
20	Alarm	Office # 3 Motion				CIE132-Interior
					N	
21	Alarm	Office # 4 Motion				CIE132-Interior
					N	
22	Alarm	Office # 5 Motion				CIE132-Interior
					N	
23	Alarm	Office # 6 Motion				CIE132-Interior
					N	
24	Alarm	Hallway Entry Motion				CIE132-Interior
					N	
25	Alarm	Office # 7 Motion				CIE132-Interior
					N	
26	Alarm	Office # 8 Motion				CIE132-Interior
					N	
27	Alarm	Office # 9 Motion				CIE132-Interior
					N	
28	Alarm	Lunch Room Motion				CIE132-Interior
					N	
29	Alarm	Upstairs Entry Door				CIE134-Entry/Exit
					N	
30	Alarm	Upstairs Entry Motion				CIE132-Interior
					N	
31	Alarm	Meeting Room Motion				CIE132-Interior
					N	
32	Alarm	Office # 11 Window				CIE131-Perimeter
					N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
33	Alarm	Office # 12 Window			CIE131-Perimeter	
			N			
34	Alarm	Office # 13 Window			CIE131-Perimeter	
			N			
35	Alarm	Office # 14 Window			CIE131-Perimeter	
			N			
36	Alarm	Office # 15 Window			CIE131-Perimeter	
			N			
37	Alarm	Office # 16 Window			CIE131-Perimeter	
			N			
38	Alarm	Office # 17 Window			CIE131-Perimeter	
			N			
39	Alarm	Office # 20 Motion			CIE132-Interior	
			N			
40	Alarm	Office # 21 Motion			CIE132-Interior	
			N			
41	Alarm	Office # 18 Window			CIE131-Perimeter	
			N			
42	Alarm	Office # 19 Window			CIE131-Perimeter	
			N			
43	Alarm	Office # 20 Window			CIE131-Perimeter	
			N			
44	Alarm	Office # 21 Window			CIE131-Perimeter	
			N			
45	Alarm	Storage Room Window			CIE131-Perimeter	
			N			
46	Alarm	Storage Room Motion			CIE132-Interior	
			N			
47	Alarm	Office # 11 Motion			CIE132-Interior	
			N			
48	Alarm	Office # 12 Motion			CIE132-Interior	
			N			
49	Alarm	Office # 13 Motion			CIE132-Interior	
			N			
50	Alarm	Office # 14 Motion			CIE132-Interior	
			N			
51	Alarm	Office # 15 Motion			CIE132-Interior	
			N			
52	Alarm	Office # 16 Motion			CIE132-Interior	
			N			
53	Alarm	Office # 17 Motion			CIE132-Interior	
			N			
54	Alarm	Office # 18 Motion			CIE132-Interior	
			N			
55	Alarm	Office # 19 Motion			CIE132-Interior	
			N			
56	Alarm	Office # 23 Motion			CIE132-Interior	
			N			
57	Alarm	Office # 22 Motion			CIE132-Interior	
			N			
58	Alarm	North Hall Motion			CIE132-Interior	
			N			
59	Alarm	South East Second Floor Fire Door			CIE131-Perimeter	
			N			

Installer# First to Last			CS# First to Last			Corporate Account 2026		
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
60	Alarm	Computer Room Temperature Alarm			CIE150-Alarm (24-hour non-burglary)			
			Y					
O/C	Armed				SE-05-LOG ONLY CLOSE			
	1		N					
O/C	Disarm				SE-04-LOG ONLY OPEN			
	1		N					

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000086	CITY OF COQUITLAM 1250 PIPELINE ROAD TOWN CENTER WORKSYARD COQUITLAM, BC V3B 4S1	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 221303			System Type V128 Vista 128					
ATI Hours 26 Minutes			ATI Late Event# G-NOTT			Active Date 6/30/2010		
Alt ATI Hours Minutes			ATI Global					
ATI Option 2-Timer Test Only			ATI Page					
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
1	Alarm	Office Entry Door			CIE134-Entry/Exit			
			N					
2	Alarm	Office Hall Motion			CIE132-Interior			
			N					
3	Alarm	Shop Entry Door			CIE131-Perimeter			
			N					
4	Alarm	Shop Overhead Door			CIE131-Perimeter			
			N					
5	Alarm	Shop Motion			CIE132-Interior			
			N					
6	Alarm	Office 1 Motion			CIE132-Interior			
			N					
7	Alarm	Office 2 Motion			CIE132-Interior			
			N					
8	Alarm	Lunch Room Motion			CIE132-Interior			
			N					
9	Alarm	Lunch Room Door			CIE134-Entry/Exit			
			N					
O/C	Armed				SE-05-LOG ONLY CLOSE			
	1		N					
O/C	Disarm				SE-04-LOG ONLY OPEN			
	1		N					

Installer# First to Last

CS# First to Last

Corporate Account 2026

CS# 111303		System Type WINC Radio Communicator				
ATI Hours	26	Minutes	ATI Late Event#	W-NOTT	Active Date	7/5/2010
Alt ATI Hours		Minutes	ATI Global			
ATI Option			ATI Page			
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment Type		
1	Alarm	Siren Trip			151-BURGLAR ALARM	
			Y			
801	Alarm				302-WINC LOW BATTERY	
			N			
809	Alarm				301-WINC POWER LOSS	
			N			
CS# 131303		System Type WINC Radio Communicator				
ATI Hours		Minutes	ATI Late Event#		Active Date	7/5/2010
Alt ATI Hours		Minutes	ATI Global			
ATI Option			ATI Page			
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment Type		
1	Alarm	Office Entry Door			CIE134-Entry/Exit	
			N			
2	Alarm	Office Hall Motion			CIE132-Interior	
			N			
3	Alarm	Shop Entry Door			CIE131-Perimeter	
			N			
4	Alarm	Shop Overhead Door			CIE131-Perimeter	
			N			
5	Alarm	Shop Motion			CIE132-Interior	
			N			
6	Alarm	Office Motion 1			CIE132-Interior	
			N			
7	Alarm	Office Motion 2			CIE132-Interior	
			N			
8	Alarm	Lunch Room Motion			CIE132-Interior	
			N			
9	Alarm	Lunch Room Door			CIE134-Entry/Exit	
			N			
O/C	Armed				SE-05-LOG ONLY CLOSE	
	1		N			
O/C	Disarm				SE-04-LOG ONLY OPEN	
	1		N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000088	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	633 POIRIER STREET	Yes		Active	
	SPORTS AND LEISURE COMPLEX	Cross Street			
	COQUITLAM, BC V3J 6A9	Codewords			
604-927-6027	604-937-7083	Corporate Account		2026-CITY OF COQUITLAM	
Installing Company 3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 222181			System Type V128 Vista 128					
ATI Hours 26 Minutes			ATI Late Event# G-NOTT			Active Date 9/20/2010		
Alt ATI Hours Minutes			ATI Global					
ATI Option 2-Timer Test Only			ATI Page					
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
1	Alarm				CIE110-FIRE ALARM - CALL PREM			
			Y					
1	Trouble				CIE373-FIRE TROUBLE			
			Y					
2	Alarm				CIE373-FIRE TROUBLE			
			Y					
2	Trouble				CIE373-FIRE TROUBLE			
			Y					
3	Alarm				CIE200-FIRE SUPERVISORY Alert			
			Y					
3	Trouble				CIE373-FIRE TROUBLE			
			Y					
10	Alarm	Wireless Panic Button			97-HOLD UP ALARM			
			Y					
11	Alarm	Wireless Panic Button			97-HOLD UP ALARM			
			Y					
12	Alarm	Wireless Panic Button			97-HOLD UP ALARM			
			Y					
13	Alarm	Wireless Panic Button			97-HOLD UP ALARM			
			Y					
14	Alarm	Wireless Panic Button			97-HOLD UP ALARM			
			Y					
15	Alarm	Wireless Panic Button			97-HOLD UP ALARM			
			Y					
O/C	Armed				SE-05-LOG ONLY CLOSE			
	1		N					
O/C	Disarm				SE-04-LOG ONLY OPEN			
	1		N					

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000101	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	630 POIRIER STREET	Yes		Active	
	POIRIER COMMUNITY CENTRE(BURG)	Cross Street			
	COQUITLAM, BC V3J 6B1	Codewords			
	604-927-6027	Corporate Account		2026-CITY OF COQUITLAM	
	Installing Company 3511-COQUITLAM COMMERCIAL	Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 221916		System Type V128 Vista 128		Active Date 2/27/2012	
ATI Hours	Minutes	ATI Late Event#			
Alt ATI Hours	Minutes	ATI Global			
ATI Option		ATI Page			
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm	Front Door North			CIE134-Entry/Exit
				N	
2	Alarm	Front Door South			CIE134-Entry/Exit
				N	
3	Alarm	Howe Room Door			CIE131-Perimeter
				N	
4	Alarm	MacDonald - Cartier Room South Door			CIE131-Perimeter
				N	
5	Alarm	MacDonald - Cartier Room North Door			CIE131-Perimeter
				N	
6	Alarm	Kitchen Door			CIE134-Entry/Exit
				N	
17	Alarm	Kitchen Storage Room Door			CIE131-Perimeter
				N	
22	Alarm	Entrance Motion			CIE132-Interior
				N	
24	Alarm	Galt Room Motion			CIE132-Interior
				N	
25	Alarm	Howe Room Motion			CIE132-Interior
				N	
26	Alarm	MacDonald - Cartier Room South Motion			CIE132-Interior
				N	
31	Alarm	Front Office Motion			CIE132-Interior
				N	
33	Alarm	MacDonald - Cartier Room North Motion			CIE132-Interior
				N	
34	Alarm	McGee Room Motion			CIE132-Interior
				N	
35	Alarm	N.E. Hallway Motion			CIE132-Interior
				N	
36	Alarm	S.E Hallway Motion			CIE132-Interior
				N	
37	Alarm	Back Office Motion			CIE132-Interior
				N	
41	Alarm	Teen Room Door			CIE131-Perimeter
				N	
42	Alarm	Teen Room Motion			CIE132-Interior
				N	
43	Alarm	Downstairs Hallway Door			CIE131-Perimeter
				N	
44	Alarm	Downstairs Hallway Motion			CIE132-Interior
				N	
51	Alarm	Front Door North			CIE134-Entry/Exit
				N	
52	Alarm	Front Door South			CIE134-Entry/Exit
				N	
O/C	Armed				SE-05-LOG ONLY CLOSE
	1			N	
O/C	Disarm				SE-04-LOG ONLY OPEN
	1			N	

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 281068		System Type ANETG Alarmnet GSM Radio		Active Date 2/27/2012	
ATI Hours		Minutes		ATI Late Event#	
Alt ATI Hours		Minutes		ATI Global	
ATI Option				ATI Page	
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm	Front Door North			CIE134-Entry/Exit
				N	
2	Alarm	Front Door South			CIE134-Entry/Exit
				N	
3	Alarm	Howe Room Door			CIE131-Perimeter
				N	
4	Alarm	MacDonald - Cartier Room South Door			CIE131-Perimeter
				N	
5	Alarm	MacDonald - Cartier Room North Door			CIE131-Perimeter
				N	
6	Alarm	Kitchen Door			CIE134-Entry/Exit
				N	
17	Alarm	Kitchen Storage Room Door			CIE131-Perimeter
				N	
22	Alarm	Entrance Motion			CIE132-Interior
				N	
24	Alarm	Galt Room Motion			CIE132-Interior
				N	
25	Alarm	Howe Room Motion			CIE132-Interior
				N	
26	Alarm	MacDonald - Cartier Room South Motion			CIE132-Interior
				N	
28	Alarm	Hallway Motion Near Macdonald Room			CIE132-Interior
				N	
31	Alarm	Front Office Motion			CIE132-Interior
				N	
33	Alarm	MacDonald - Cartier Room North Motion			CIE132-Interior
				N	
34	Alarm	McGee Room Motion			CIE132-Interior
				N	
35	Alarm	N.E. Hallway Motion			CIE132-Interior
				N	
36	Alarm	S.E Hallway Motion			CIE132-Interior
				N	
37	Alarm	Back Office Motion			CIE132-Interior
				N	
41	Alarm	Teen Room Door			CIE131-Perimeter
				N	
42	Alarm	Teen Room Motion			CIE132-Interior
				N	
43	Alarm	Downstairs Hallway Door			CIE131-Perimeter
				N	
44	Alarm	Downstairs Hallway Motion			CIE132-Interior
				N	
51	Alarm	Front Door North			CIE134-Entry/Exit
				N	
52	Alarm	Front Door South			CIE134-Entry/Exit
				N	
O/C	Armed				SE-05-LOG ONLY CLOSE
	1			N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment Type		
O/C	Disarm				SE-04-LOG ONLY OPEN	
	1		N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000101	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	1655 WINSLOW AVENUE	Yes		Active	
	DOGWOOD PAVILLION	Cross Street			
	COQUITLAM, BC V3J 6B1	Codewords			
	604-927-6098	604-927-6944	Corporate Account	2026-CITY OF COQUITLAM	
	Installing Company	3511-COQUITLAM COMMERCIAL	Service Company	3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 220155		System Type V128 Vista 128		Active Date 2/15/2012	
ATI Hours	Minutes	ATI Late Event#			
Alt ATI Hours	Minutes	ATI Global			
ATI Option		ATI Page			
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm	S Ent Door E			CIE134-Entry/Exit
				N	
2	Alarm	S Ent Door W			CIE134-Entry/Exit
				N	
3	Alarm	E Entry Door			CIE134-Entry/Exit
				N	
4	Alarm	Pool room Door			CIE131-Perimeter
				N	
5	Alarm	Liquor Room Door			CIE131-Perimeter
				N	
6	Alarm	WoodWork Window			CIE131-Perimeter
				N	
7	Alarm	North East Hall Door West			CIE131-Perimeter
				N	
8	Alarm	North East Hall Door East			CIE131-Perimeter
				N	
9	Alarm	Kitchen Door			CIE131-Perimeter
				N	
10	Alarm	RECEPTION HOLD UP SOUTH			97-HOLD UP ALARM
				N	
11	Alarm	RECEPTION HOLD UP NORTH			97-HOLD UP ALARM
				N	
12	Alarm	Dining Door West			CIE131-Perimeter
				N	
13	Alarm	Crafts Room Door			CIE131-Perimeter
				N	
14	Alarm	West Exit			CIE131-Perimeter
				N	
15	Alarm	Coffee Room Door			CIE131-Perimeter
				N	
16	Alarm	S Ent Motion West			CIE132-Interior
				N	
17	Alarm	S Entry Motion E			CIE132-Interior
				N	
18	Alarm	S Entry Office			CIE132-Interior
				N	
19	Alarm	Comp - Cordina			CIE131-Perimeter
				N	
20	Alarm	Teagarden West			CIE132-Interior
				N	
21	Alarm	Teagarden East			CIE132-Interior
				N	
22	Alarm	Coffee Room IR			CIE134-Entry/Exit
				N	
23	Alarm	S Ent Office			CIE134-Entry/Exit
				N	
24	Alarm	E Entr Motion			CIE132-Interior
				N	
25	Alarm	S Pool room Motion			CIE132-Interior
				N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
26	Alarm	N Pool Room Motion			CIE132-Interior	
			N			
27	Alarm	Mini Meeting			CIE132-Interior	
			N			
28	Alarm	workshop Motion			CIE132-Interior	
			N			
29	Alarm	Woodwork Motion			CIE132-Interior	
			N			
30	Alarm	N Hall Motion			CIE132-Interior	
			N			
31	Alarm	Kit Hall Motion			CIE132-Interior	
			N			
32	Alarm	Kit Motion			CIE132-Interior	
			N			
33	Alarm	Dinning Motion			CIE132-Interior	
			N			
34	Alarm	Craft Room Motion			CIE132-Interior	
			N			
35	Alarm	N Lounge Motion			CIE132-Interior	
			N			
36	Alarm	S Lounge Motion			CIE132-Interior	
			N			
37	Alarm	W Exit Motion			CIE132-Interior	
			N			
38	Alarm	Dogwood Motion			CIE132-Interior	
			N			
39	Alarm	Card Room Motion			CIE132-Interior	
			N			
40	Alarm	Auditorium E			CIE132-Interior	
			N			
41	Alarm				CIE110-FIRE ALARM - CALL PREM	
			N			
42	Alarm				CIE373-FIRE TROUBLE	
			N			
43	Alarm				CIE200-FIRE SUPERVISORY Alert	
			N			
60	Alarm	Mens Washroom Motion			CIE132-Interior	
			N			
61	Alarm	Womens Washroom Motion			CIE132-Interior	
			N			
62	Alarm	BOLVARD CAFE CASH LINE HOLD UP			97-HOLD UP ALARM	
			Y			
63	Alarm	BOLVARD CAFE CASH OFFICE HOLD UP			97-HOLD UP ALARM	
			Y			
O/C	Armed				SE-05-LOG ONLY CLOSE	
	1		N			
O/C	Disarm				SE-04-LOG ONLY OPEN	
	1		N			

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026		
CS# 281089		System Type ANETG Alarmnet GSM Radio		Active Date 2/20/2012		
ATI Hours		ATI Late Event#				
Alt ATI Hours		ATI Global				
ATI Option		ATI Page				
Zone	State	Location/Comment		Page	GL Page	Event
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type	Type
1	Alarm	S Ent Door E				CIE134-Entry/Exit
				N		
2	Alarm	S Ent Door W				CIE134-Entry/Exit
				N		
3	Alarm	E Entry Door				CIE134-Entry/Exit
				N		
4	Alarm	Pool room Door				CIE131-Perimeter
				N		
5	Alarm	Liquor Room Door				CIE131-Perimeter
				N		
6	Alarm	WoodWork Window				CIE131-Perimeter
				N		
7	Alarm	North East Hall Door West				CIE131-Perimeter
				N		
8	Alarm	North East Hall Door East				CIE131-Perimeter
				N		
9	Alarm	Kitchen Door				CIE131-Perimeter
				N		
10	Alarm	RECEPTION HOLD UP SOUTH				97-HOLD UP ALARM
				N		
11	Alarm	RECEPTION HOLD UP NORTH				97-HOLD UP ALARM
				N		
12	Alarm	Dining Door West				CIE131-Perimeter
				N		
13	Alarm	Crafts Room Door				CIE131-Perimeter
				N		
14	Alarm	West Exit				CIE131-Perimeter
				N		
15	Alarm	Coffee Room Door				CIE131-Perimeter
				N		
16	Alarm	S Ent Motion West				CIE132-Interior
				N		
17	Alarm	S Entry Motion E				CIE132-Interior
				N		
18	Alarm	S Entry Office				CIE132-Interior
				N		
19	Alarm	Comp - Cordina				CIE131-Perimeter
				N		
20	Alarm	Teagarden West				CIE132-Interior
				N		
21	Alarm	Teagarden East				CIE132-Interior
				N		
22	Alarm	Coffee Room IR				CIE134-Entry/Exit
				N		
23	Alarm	S Ent Office				CIE134-Entry/Exit
				N		
24	Alarm	E Entr Motion				CIE132-Interior
				N		
25	Alarm	S Pool room Motion				CIE132-Interior
				N		

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
26	Alarm	N Pool Room Motion			CIE132-Interior	
			N			
27	Alarm	Mini Meeting			CIE132-Interior	
			N			
28	Alarm	workshop Motion			CIE132-Interior	
			N			
29	Alarm	Woodwork Motion			CIE132-Interior	
			N			
30	Alarm	N Hall Motion			CIE132-Interior	
			N			
31	Alarm	Kit Hall Motion			CIE132-Interior	
			N			
32	Alarm	Kit Motion			CIE132-Interior	
			N			
33	Alarm	Dinning Motion			CIE132-Interior	
			N			
34	Alarm	Craft Room Motion			CIE132-Interior	
			N			
35	Alarm	N Lounge Motion			CIE132-Interior	
			N			
36	Alarm	S Lounge Motion			CIE132-Interior	
			N			
37	Alarm	W Exit Motion			CIE132-Interior	
			N			
38	Alarm	Dogwood Motion			CIE132-Interior	
			N			
39	Alarm	Card Room Motion			CIE132-Interior	
			N			
40	Alarm	Auditorium E			CIE132-Interior	
			N			
41	Alarm				CIE110-FIRE ALARM - CALL PREM	
			N			
42	Alarm				CIE373-FIRE TROUBLE	
			N			
43	Alarm				CIE200-FIRE SUPERVISORY Alert	
			N			
60	Alarm	Mens Washroom Motion			CIE132-Interior	
			N			
61	Alarm	Womens Washroom Motion			CIE132-Interior	
			N			
62	Alarm	BOLVARD CAFE CASH LINE HOLD UP			97-HOLD UP ALARM	
			Y			
63	Alarm	BOLVARD CAFE CASH OFFICE HOLD UP			97-HOLD UP ALARM	
			Y			
O/C	Armed				SE-05-LOG ONLY CLOSE	
	1		N			
O/C	Disarm				SE-04-LOG ONLY OPEN	
	1		N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000111	CITY OF COQUITLAM 1207 PINETREE WAY INNOVATION CENTER COQUITLAM, BC 604-927-6950	Pacific Time Zone Yes Cross Street Codewords		Commercial Active	
Installing Company 3511-COQUITLAM COMMERCIAL		Corporate Account 2026-CITY OF COQUITLAM		Service Company 3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 221774		System Type FA1660 First Alert		Active Date 6/25/2012	
ATI Hours	Minutes	ATI Late Event#			
Alt ATI Hours	Minutes	ATI Global			
ATI Option		ATI Page			
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm	FRONT RED EXIT DOOR RIGHT			CIE134-Entry/Exit
				N	
2	Alarm	FRONT RED EXIT DOOR LEFT			CIE134-Entry/Exit
				N	
3	Alarm	BOARD ROOM 360 MOTION			CIE132-Interior
				N	
4	Alarm	LIBRARY MOTION			CIE132-Interior
				N	
5	Alarm	LIBRARY DOOR RIGHT			CIE131-Perimeter
				N	
6	Alarm	LIBRARY DOOR LEFT			CIE131-Perimeter
				N	
7	Alarm	LOWER FIRE EXIT STAIR DOOR			CIE131-Perimeter
				N	
8	Alarm	LOWER RECEPTION MOTION			CIE132-Interior
				N	
17	Alarm	ENTRY DOOR RIGHT			CIE134-Entry/Exit
				N	
18	Alarm	ENTRY DOOR LEFT			CIE134-Entry/Exit
				N	
19	Alarm	RIGHT LAKE DOOR RIGHT			CIE131-Perimeter
				N	
20	Alarm	RIGHT LAKE DOOR LEFT			CIE131-Perimeter
				N	
21	Alarm	MID LAKE DOOR RIGHT			CIE131-Perimeter
				N	
22	Alarm	MIDE LAKE DOOR LEFT			CIE131-Perimeter
				N	
23	Alarm	LEFT LAKE DOOR RIGHT			CIE131-Perimeter
				N	
24	Alarm	LEFT LAKE DOOR LEFT			CIE131-Perimeter
				N	
25	Alarm	ROOF HATCH			CIE131-Perimeter
				N	
26	Alarm	STAIR DOOR			CIE131-Perimeter
				N	
27	Alarm	EAST FIRE EXIT DOOR			CIE131-Perimeter
				N	
28	Alarm	BATH HALL DOOR			CIE131-Perimeter
				N	
29	Alarm	SOUTH 360 MOTION			CIE132-Interior
				N	
30	Alarm	360 MOTION			CIE132-Interior
				N	
33	Alarm	FRASER ROOM DOOR RIGHT			CIE131-Perimeter
				N	
34	Alarm	FRASER ROOM DOOR LEFT			CIE131-Perimeter
				N	
35	Alarm	FRASER ROOM MOTION			CIE132-Interior
				N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
41	Alarm	Front Door			CIE134-Entry/Exit	
			N			
42	Alarm	Front Entry Door			CIE134-Entry/Exit	
			N			
43	Alarm	Back Door			CIE131-Perimeter	
			N			
44	Alarm	Glassbreak Sensor			CIE131-Perimeter	
			N			
45	Alarm	Front Motion			CIE132-Interior	
			N			
46	Alarm	Back Motion			CIE132-Interior	
			N			
O/C	Armed				SE-05-LOG ONLY CLOSE	
	1		N			
O/C	Disarm				SE-04-LOG ONLY OPEN	
	1		N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 280197		System Type ANETG Alarmnet GSM Radio		Active Date 6/26/2012	
ATI Hours		ATI Late Event#			
Alt ATI Hours		ATI Global			
ATI Option		ATI Page			
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm	FRONT RED EXIT DOOR RIGHT			CIE134-Entry/Exit
				N	
2	Alarm	FRONT RED EXIT DOOR LEFT			CIE134-Entry/Exit
				N	
3	Alarm	BOARD ROOM 360 MOTION			CIE132-Interior
				N	
4	Alarm	LIBRARY MOTION			CIE132-Interior
				N	
5	Alarm	LIBRARY DOOR RIGHT			CIE131-Perimeter
				N	
6	Alarm	LIBRARY DOOR LEFT			CIE131-Perimeter
				N	
7	Alarm	LOWER FIRE EXIT STAIR DOOR			CIE131-Perimeter
				N	
8	Alarm	LOWER RECEPTION MOTION			CIE132-Interior
				N	
17	Alarm	ENTRY DOOR RIGHT			CIE134-Entry/Exit
				N	
18	Alarm	ENTRY DOOR LEFT			CIE134-Entry/Exit
				N	
19	Alarm	RIGHT LAKE DOOR RIGHT			CIE131-Perimeter
				N	
20	Alarm	RIGHT LAKE DOOR LEFT			CIE131-Perimeter
				N	
21	Alarm	MID LAKE DOOR RIGHT			CIE131-Perimeter
				N	
22	Alarm	MIDE LAKE DOOR LEFT			CIE131-Perimeter
				N	
23	Alarm	LEFT LAKE DOOR RIGHT			CIE131-Perimeter
				N	
24	Alarm	LEFT LAKE DOOR LEFT			CIE131-Perimeter
				N	
25	Alarm	ROOF HATCH			CIE131-Perimeter
				N	
26	Alarm	STAIR DOOR			CIE131-Perimeter
				N	
27	Alarm	EAST FIRE EXIT DOOR			CIE131-Perimeter
				N	
28	Alarm	BATH HALL DOOR			CIE131-Perimeter
				N	
29	Alarm	SOUTH 360 MOTION			CIE132-Interior
				N	
30	Alarm	360 MOTION			CIE132-Interior
				N	
33	Alarm	FRASER ROOM DOOR RIGHT			CIE131-Perimeter
				N	
34	Alarm	FRASER ROOM DOOR LEFT			CIE131-Perimeter
				N	
35	Alarm	FRASER ROOM MOTION			CIE132-Interior
				N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type	
41	Alarm	Front Door			CIE134-Entry/Exit	
			N			
42	Alarm	Front Entry Door			CIE134-Entry/Exit	
			N			
43	Alarm	Back Door			CIE131-Perimeter	
			N			
44	Alarm	Glassbreak Sensor			CIE131-Perimeter	
			N			
45	Alarm	Front Motion			CIE132-Interior	
			N			
46	Alarm	Back Motion			CIE132-Interior	
			N			
O/C	Armed				SE-05-LOG ONLY CLOSE	
	1		N			
O/C	Disarm				SE-04-LOG ONLY OPEN	
	1		N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000121	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	1171 PINETREE WAY	Yes		Active	
	ARCHIVES	Cross Street			
	COQUITLAM, BC V3B 0Y1	Codewords			
	604-927-3907	Corporate Account		2026-CITY OF COQUITLAM	
	Installing Company 3511-COQUITLAM COMMERCIAL	Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Gen Dispatch Permanent **Effective Date** 2/8/2013 00:00 **Expire Date**
 CALL ALL PRS BEFORE DISPATCHING PD. CALL
 LIST RESPONDER WILL DECIDE IF PD IS

CS# 221537	System Type V128 Vista 128		ATI Late Event# G-NOTT	Active Date 2/6/2013
ATI Hours 175	Minutes	ATI Global		
Alt ATI Hours	Minutes	ATI Page		
ATI Option				
Zone	State	Location/Comment	Page	GL Page
GL Sch	Sch#	Alarm Group	Restore?	Equipment Type
4	Alarm	SOUTH WEST MOTION		CIE132-Interior
			N	
26	Alarm	Archives Reception Panic		79-PANIC - CALL PREM
			N	
27	Alarm	Archives Filing Panic		79-PANIC - CALL PREM
			N	
34	Alarm	West Left Door		CIE134-Entry/Exit
			N	
35	Alarm	West Right Door		CIE131-Perimeter
			N	
36	Alarm	Entry Motion		CIE132-Interior
			N	
37	Alarm	Central Motion		CIE132-Interior
			N	
O/C	Armed			SE-05-LOG ONLY CLOSE
	1		N	
O/C	Disarm			SE-04-LOG ONLY OPEN
	1		N	

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000121	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	3435 VICTORIA DRIVE	Yes		Active	
	VICTORIA HALL	Cross Street			
	COQUITLAM, BC V3B 3H7	Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 222452			System Type V128 Vista 128					
ATI Hours 175 Minutes			ATI Late Event# G-NOTT			Active Date 2/8/2013		
Alt ATI Hours Minutes			ATI Global					
ATI Option 2-Timer Test Only			ATI Page					
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
1	Alarm				33-FIRE - DISPATCH 1ST			
			Y					
1	Trouble				CIE373-FIRE TROUBLE			
			Y					
2	Alarm				CIE373-FIRE TROUBLE			
			Y					
2	Trouble				CIE373-FIRE TROUBLE			
			Y					
E333	Trouble	Cell Failure			850-TROUBLE			
			N					
R333	Restore	Cell Failure Restore			2000-RESTORE			
			N					
CS# 280157			System Type ANETG Alarmnet GSM Radio					
ATI Hours 26 Minutes			ATI Late Event# G-NOTT			Active Date 2/8/2013		
Alt ATI Hours Minutes			ATI Global					
ATI Option			ATI Page					
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
1	Alarm				33-FIRE - DISPATCH 1ST			
			Y					
1	Trouble				CIE373-FIRE TROUBLE			
			Y					
2	Alarm				CIE373-FIRE TROUBLE			
			Y					
2	Trouble				CIE373-FIRE TROUBLE			
			Y					
E333	Trouble	Cell Failure			850-TROUBLE			
			N					
R333	Restore	Cell Failure Restore			2000-RESTORE			
			N					

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000124	CITY OF COQUITLAM 2200 DAWES HILL ROAD DAWES HILL STORAGE COQUITLAM, BC	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
11-PORT COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 222795			System Type V128 Vista 128					
ATI Hours		Minutes	ATI Late Event#		Active Date			
Alt ATI Hours		Minutes	ATI Global					
ATI Option			ATI Page					
Zone	State	Location/Comment		Page	GL Page	Event		
GL Sch	Sch#	Alarm Group		Restore?	Equipment	Type		
1	Alarm	Front Door				CIE134-Entry/Exit		
				N				
2	Alarm	Front Door				CIE131-Perimeter		
				N				
3	Alarm	Front Motion				CIE132-Interior		
				N				
4	Alarm	Back Motion				CIE132-Interior		
				N				
O/C	Armed					SE-05-LOG ONLY CLOSE		
	1			N				
O/C	Disarm					SE-04-LOG ONLY OPEN		
	1			N				

CS# 132795			System Type WINC Radio Communicator					
ATI Hours		26	Minutes	ATI Late Event# G-NOTT		Active Date 4/26/2013		
Alt ATI Hours			Minutes	ATI Global				
ATI Option		2-Timer Test Only		ATI Page				
Zone	State	Location/Comment		Page	GL Page	Event		
GL Sch	Sch#	Alarm Group		Restore?	Equipment	Type		
1	Alarm	Front Door				CIE134-Entry/Exit		
				N				
2	Alarm	Front Door				CIE131-Perimeter		
				N				
3	Alarm	Front Motion				CIE132-Interior		
				N				
4	Alarm	Back Motion				CIE132-Interior		
				N				
O/C	Armed					SE-05-LOG ONLY CLOSE		
	1			N				
O/C	Disarm					SE-04-LOG ONLY OPEN		
	1			N				

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 112795		System Type WINC Radio Communicator			
ATI Hours 24		Minutes 15		ATI Late Event# W-NOTT	
Alt ATI Hours		Minutes		Active Date 4/26/2013	
ATI Option 2-Timer Test Only		ATI Global			
		ATI Page			
Zone	State	Location/Comment	Page	GL Page	Event
GL Sch	Sch#	Alarm Group	Restore?	Equipment Type	
1	Alarm	Siren Trip			151-BURGLAR ALARM
			N		
801	Trouble				302-WINC LOW BATTERY
			N		
809	Trouble				301-WINC POWER LOSS
			N		

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000128	CITY OF COQUITLAM 1746 BRUNETTE AVENUE BOOTH FARMHOUSE COQUITLAM, BC V3K 1H2	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

CS# 221806 System Type VIST20 VISTA 20

ATI Hours

Minutes

ATI Late Event#

Active Date

Alt ATI Hours

Minutes

ATI Global

ATI Option

ATI Page

CS# 280136 System Type ANETC Alarmnet Cellular Backup

ATI Hours

Minutes

ATI Late Event#

Active Date 8/28/2013

Alt ATI Hours

Minutes

ATI Global

ATI Option

ATI Page

Zone	State	Location/Comment	Page	GL Page	Event
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type
1	Alarm	BASEMENT SMOKE	N		CIE110-FIRE ALARM - CALL PREM
2	Alarm	FRONT DOOR	N		CIE134-Entry/Exit
3	Alarm	BACK INNER DOOR	N		CIE131-Perimeter
4	Alarm	MAIN FLOOR HALL MOTION	N		CIE132-Interior
5	Alarm	BASEMENT INNER DOOR	N		CIE131-Perimeter
6	Alarm	STAIRWELL DOOR	N		CIE131-Perimeter
7	Alarm	BASEMENT MOTION	N		CIE132-Interior
O/C	Armed		N		SE-05-LOG ONLY CLOSE
	1		N		
O/C	Disarm		N		SE-04-LOG ONLY OPEN
	1		N		

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000130	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	1210 PINETREE WAY	Yes		Active	
	CENTRAL CITY AQUATIC CENTER	Cross Street			
	COQUITLAM, BC V3B 7T8	Codewords			
604-927-6999	604-375-3014	Corporate Account		2026-CITY OF COQUITLAM	
Installing Company	3511-COQUITLAM COMMERCIAL	Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

e

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 221152		System Type V128 Vista 128			
ATI Hours 26		Minutes		ATI Late Event# G-NOTT	
Alt ATI Hours		Minutes		Active Date 9/26/2013	
ATI Option				ATI Global	
				ATI Page	
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm				CIE110-FIRE ALARM - CALL PREM
				Y	
1	Trouble				CIE373-FIRE TROUBLE
				Y	
2	Alarm				CIE373-FIRE TROUBLE
				Y	
2	Trouble				CIE373-FIRE TROUBLE
				Y	
12	Alarm	Leisure Side Double Door			CIE134-Entry/Exit
				N	
13	Alarm	Mechanical Room Double DOor			CIE131-Perimeter
				N	
14	Alarm	Chlorine Room Door			CIE131-Perimeter
				N	
15	Alarm	Main Electrical Room Door			CIE131-Perimeter
				N	
16	Alarm	S.E. Emergency Exit Pool Deck			CIE134-Entry/Exit
				N	
17	Alarm	Roof Top Door - Dry Mechanical Penthouse			CIE131-Perimeter
				N	
18	Alarm	Roof Top Door - Above Mechanical Room			CIE131-Perimeter
				N	
19	Alarm	Front Entrance Inside Sliding Doors			CIE131-Perimeter
				N	
20	Alarm	Gym Exit Side Door			CIE131-Perimeter
				N	
21	Alarm	Halway Emergency Exit Door			CIE131-Perimeter
				N	
22	Alarm	Studio Room Door			CIE131-Perimeter
				N	
23	Alarm	Front Entrance Motion			CIE131-Perimeter
				N	
30	Alarm	POS 1 Hold Up			97-HOLD UP ALARM
				N	
31	Alarm	POS 2 Hold Up			97-HOLD UP ALARM
				N	
32	Alarm	POS 3 Hold Up			97-HOLD UP ALARM
				N	
O/C	Armed				SE-05-LOG ONLY CLOSE
	1			N	
O/C	Disarm				SE-04-LOG ONLY OPEN
	1			N	

Installer# First to Last

CS# First to Last

Corporate Account 2026

CS# 111152 System Type WINC Radio Communicator

ATI Hours 72 Minutes 0 ATI Late Event# W-NOTT Active Date 9/26/2013

Alt ATI Hours Minutes ATI Global

ATI Option 2-Timer Test Only ATI Page

Zone	State	Location/Comment	Page	GL Page	Event
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type
1	Alarm	Siren Trip	N		151-BURGLAR ALARM
801	Alarm		N		302-WINC LOW BATTERY
809	Alarm		N		301-WINC POWER LOSS

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 131152		System Type WINC Radio Communicator		Active Date 9/26/2013	
ATI Hours	Minutes	ATI Late Event#			
Alt ATI Hours	Minutes	ATI Global			
ATI Option		ATI Page			
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm				CIE110-FIRE ALARM - CALL PREM
				Y	
1	Trouble				CIE373-FIRE TROUBLE
				Y	
2	Alarm				CIE373-FIRE TROUBLE
				Y	
2	Trouble				CIE373-FIRE TROUBLE
				Y	
12	Alarm	Leisure Side Double Door			CIE134-Entry/Exit
				N	
13	Alarm	Mechanical Room Double DOor			CIE131-Perimeter
				N	
14	Alarm	Chlorine Room Door			CIE131-Perimeter
				N	
15	Alarm	Main Electrical Room Door			CIE131-Perimeter
				N	
16	Alarm	S.E. Emergency Exit Pool Deck			CIE134-Entry/Exit
				N	
17	Alarm	Roof Top Door - Dry Mechanical Penthouse			CIE131-Perimeter
				N	
18	Alarm	Roof Top Door - Above Mechanical Room			CIE131-Perimeter
				N	
19	Alarm	Front Entrance Inside Sliding Doors			CIE131-Perimeter
				N	
20	Alarm	Gym Exit Side Door			CIE131-Perimeter
				N	
21	Alarm	Halway Emergency Exit Door			CIE131-Perimeter
				N	
22	Alarm	Studio Room Door			CIE131-Perimeter
				N	
23	Alarm	Front Entrance Motion			CIE131-Perimeter
				N	
30	Alarm	POS 1 Hold Up			97-HOLD UP ALARM
				N	
31	Alarm	POS 2 Hold Up			97-HOLD UP ALARM
				N	
32	Alarm	POS 3 Hold Up			97-HOLD UP ALARM
				N	
O/C	Armed				SE-05-LOG ONLY CLOSE
	1			N	
O/C	Disarm				SE-04-LOG ONLY OPEN
	1			N	

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000150	CITY OF COQUITLAM	Pacific Time Zone		ULC Account	
	3501 DAVID AVENUE	Yes		Active	
	FIRE HALL	Cross Street			
	COQUITLAM, BC V3E 0H7	Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3811-COQUITLAM ULC ACCOUNT		Service Company		3811-COQUITLAM ULC ACCOUNT	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Gen Dispatch Permanent Effective Date 12/2/2014 16:09 Expire Date

CS# 22F173		System Type VIST32 Vista 32 FB Fire panel			
ATI Hours	26	Minutes	ATI Late Event#	G-NOTT	Active Date 12/1/2014
Alt ATI Hours		Minutes	ATI Global		
ATI Option			ATI Page		
Zone	State	Location/Comment	Page	GL Page	Event
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type
1	Alarm				33-FIRE - DISPATCH 1ST
			Y		
1	Trouble				CIE373-FIRE TROUBLE
			Y		
2	Alarm				CIE373-FIRE TROUBLE
			Y		
2	Trouble				CIE373-FIRE TROUBLE
			Y		
3	Alarm				CIE200-FIRE SUPERVISORY Alert
			Y		
3	Trouble				CIE373-FIRE TROUBLE
			Y		
E333	Alarm	CELL FAILURE			850-TROUBLE
			Y		
R333	Restore	CELL FAILURE			2000-RESTORE
			N		

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 280129			System Type ANETG Alarmnet GSM Radio					
ATI Hours		26	Minutes		ATI Late Event# G-NOTT	Active Date 12/1/2014		
Alt ATI Hours			Minutes		ATI Global			
ATI Option					ATI Page			
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?		Equipment Type	
1	Alarm						33-FIRE - DISPATCH 1ST	
					Y			
1	Trouble						CIE373-FIRE TROUBLE	
					Y			
2	Alarm						CIE373-FIRE TROUBLE	
					Y			
2	Trouble						CIE373-FIRE TROUBLE	
					Y			
3	Alarm						CIE200-FIRE SUPERVISORY Alert	
					Y			
3	Trouble						CIE373-FIRE TROUBLE	
					Y			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000151	CITY OF COQUITLAM	Pacific Time Zone		ULC Account	
	618 POIRIER STREET	Yes		Active	
	DRY FLOOR FACILITY FIRE	Cross Street			
	COQUITLAM, BC	Codewords			
	604-805-6417	Corporate Account		2026-CITY OF COQUITLAM	
	Installing Company 3811-COQUITLAM ULC ACCOUNT	Service Company		3811-COQUITLAM ULC ACCOUNT	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer#	First to Last	CS#	First to Last	Corporate Account	2026
Gen Dispatch	Permanent	Effective Date	1/21/2015 16:05	Expire Date	

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 22F036		System Type VIST32 Vista 32 FB Fire panel			
ATI Hours 26		Minutes		ATI Late Event# G-NOTT	
Alt ATI Hours		Minutes		Active Date 1/20/2015	
ATI Option				ATI Global	
				ATI Page	
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm				33-FIRE - DISPATCH 1ST
				Y	
1	Trouble				CIE373-FIRE TROUBLE
				Y	
2	Alarm				CIE373-FIRE TROUBLE
				Y	
2	Trouble				CIE373-FIRE TROUBLE
				Y	
3	Alarm				CIE200-FIRE SUPERVISORY Alert
				Y	
3	Trouble				CIE373-FIRE TROUBLE
				Y	
8	Alarm	S.E. LEFT DOOR			CIE131-Perimeter
				N	
9	Alarm	S.W. RIGHT DOOR			CIE131-Perimeter
				N	
10	Alarm	S.W. LEFT DOOR			CIE131-Perimeter
				N	
11	Alarm	OHD			CIE131-Perimeter
				N	
12	Alarm	NORTH DOOR RIGHT			CIE131-Perimeter
				N	
13	Alarm	NORTH DOOR LEFT			CIE131-Perimeter
				N	
14	Alarm	N.E. RIGHT DOOR			CIE131-Perimeter
				N	
15	Alarm	N.E. LEFT DOOR			CIE131-Perimeter
				N	
16	Alarm	S.E. RIGHT DOOR			CIE131-Perimeter
				N	
E333	Trouble	CELL FAILURE			850-TROUBLE
				Y	
O/C	Armed				SE-05-LOG ONLY CLOSE
	1			N	
O/C	Disarm				SE-04-LOG ONLY OPEN
	1			N	
R333	Restore	CELL FAILURE			2000-RESTORE
				N	

Installer# First to Last

CS# First to Last

Corporate Account 2026

CS# 281222		System Type ANETG Alarmnet GSM Radio		ATI Late Event# G-NOTT		Active Date 1/20/2015	
ATI Hours 26		Minutes		ATI Global			
Alt ATI Hours		Minutes		ATI Page			
ATI Option							
Zone	State	Location/Comment		Page	GL Page	Event	
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type		
1	Alarm					33-FIRE - DISPATCH 1ST	
				Y			
1	Trouble					CIE373-FIRE TROUBLE	
				Y			
2	Alarm					CIE373-FIRE TROUBLE	
				Y			
2	Trouble					CIE373-FIRE TROUBLE	
				Y			
3	Alarm					CIE200-FIRE SUPERVISORY Alert	
				Y			
3	Trouble					CIE373-FIRE TROUBLE	
				Y			
8	Alarm	Southeast Left Door				CIE131-Perimeter	
				N			
9	Alarm	Southwest Right Door				CIE131-Perimeter	
				N			
10	Alarm	Southwest Left Door				CIE131-Perimeter	
				N			
11	Alarm	Overhead Door				CIE131-Perimeter	
				N			
12	Alarm	North Door Right				CIE131-Perimeter	
				N			
13	Alarm	North Door Left				CIE134-Entry/Exit	
				N			
14	Alarm	Northeast Door Right				CIE131-Perimeter	
				N			
15	Alarm	Northeast Door Left				CIE131-Perimeter	
				N			
16	Alarm	Southwest Door Right				CIE131-Perimeter	
				N			
E333	Trouble	CELL FAILURE				850-TROUBLE	
				Y			
O/C	Armed					SE-05-LOG ONLY CLOSE	
	1						
				N			
O/C	Disarm					SE-04-LOG ONLY OPEN	
	1						
				N			
R333	Restore	CELL FAILURE				2000-RESTORE	
				N			

Installer# First to Last		CS# First to Last	Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings	Site Type/Status	
10000153	CITY OF COQUITLAM	Pacific Time Zone	Commercial	
	618 POIRIER STREET	Yes	Active	
	DRY FLOOR FACILITY BURG	Cross Street		
	COQUITLAM, BC	Codewords		
	604-805-6417		Corporate Account	2026-CITY OF COQUITLAM
Installing Company	3511-COQUITLAM COMMERCIAL	Service Company	3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2
10-COQUITLAM PD		P	604-464-6211	
71-COQUITLAM FD		F	604-215-4826	

Installer# First to Last

CS# First to Last

Corporate Account 2026

?

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 221369			System Type VIST32 Vista 32 FB Fire panel			Active Date 1/22/2015		
ATI Hours		Minutes	ATI Late Event#					
Alt ATI Hours		Minutes	ATI Global					
ATI Option			ATI Page					
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?		Equipment Type	
8	Alarm	S.E Left Door			N		CIE131-Perimeter	
9	Alarm	S.W Right door			N		CIE131-Perimeter	
10	Alarm	S.W Left Door			N		CIE131-Perimeter	
11	Alarm	OHD			N		CIE131-Perimeter	
12	Alarm	North Door Right			N		CIE134-Entry/Exit	
13	Alarm	North Door Left			N		CIE134-Entry/Exit	
14	Alarm	N.E Right Door			N		CIE131-Perimeter	
15	Alarm	N.E Left Door			N		CIE131-Perimeter	
16	Alarm	S.E Right Door			N		CIE131-Perimeter	
O/C	Armed				N		SE-05-LOG ONLY CLOSE	
	1				N			
O/C	Disarm				N		SE-04-LOG ONLY OPEN	
	1				N			

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000154	CITY OF COQUITLAM 2689 GUILDFORD WAY EAGLE RIDGE POOL COQUITLAM, BC	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last		CS# First to Last		Corporate Account 2026		
CS# 221679		System Type VIST20 VISTA 20				
ATI Hours		Minutes	ATI Late Event#	Active Date 4/16/2015		
Alt ATI Hours		Minutes	ATI Global			
ATI Option			ATI Page			
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?		Equipment Type	
1	Alarm	MECHANICAL ROOM SMOKE	N		CIE110-FIRE ALARM - CALL PREM	
2	Alarm	MECHANICAL ENTRY DOOR	N		CIE134-Entry/Exit	
3	Alarm	MECHANICAL BACK DOOR	N		CIE131-Perimeter	
4	Alarm	STORAGE ROOM FRONT DOOR	N		CIE131-Perimeter	
5	Alarm	STORAGE ROOM BACK DOOR	N		CIE131-Perimeter	
O/C	Armed		N		SE-05-LOG ONLY CLOSE	
	1		N			
O/C	Disarm		N		SE-04-LOG ONLY OPEN	
	1		N			

CS# 281241		System Type ANETG Alarmnet GSM Radio				
ATI Hours		Minutes	ATI Late Event#	Active Date 4/16/2015		
Alt ATI Hours		Minutes	ATI Global			
ATI Option			ATI Page			
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?		Equipment Type	
1	Alarm	MECHANICAL ROOM SMOKE	N		7110-FIRE - CALL PREM.	
2	Alarm	MECHANICAL ENTRY DOOR	N		CIE134-Entry/Exit	
3	Alarm	MECHANICAL BACK DOOR	N		CIE131-Perimeter	
4	Alarm	STORAGE ROOM FRONT DOOR	N		CIE131-Perimeter	
5	Alarm	STORAGE ROOM BACK DOOR	N		CIE131-Perimeter	
6	Alarm	GUARD ROOM ENTRY	N		CIE131-Perimeter	
7	Alarm	GUARD ROOM BACK DOOR	N		CIE131-Perimeter	
8	Alarm	GUARD STAFF CHANGE ROOM ENTRY	N		CIE131-Perimeter	

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000172	CITY OF COQUITLAM	Pacific Time Zone		Commercial	
	629 HILLCREST STREET	Yes		Active	
	MUNDY PARK FIELDHOUSE	Cross Street			
	COQUITLAM, BC	Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 222110			System Type VIST21 Vista 21 Internet					
ATI Hours		Minutes	ATI Late Event#		Active Date			
Alt ATI Hours		Minutes	ATI Global					
ATI Option			ATI Page					
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?	Equipment	Type	
1	Alarm	KITCHEN MOTION					CIE132-Interior	
					N			
2	Alarm	MULTI PURPOSE ROOM 1 MOTION					CIE132-Interior	
					N			
3	Alarm	MULTI PURPOSE ROOM 2 MOTION					CIE132-Interior	
					N			
4	Alarm	CORNER STORAGE MOTION					CIE132-Interior	
					N			
5	Alarm	MIDDLE STORAGE MOTION					CIE132-Interior	
					N			
6	Alarm	ELECTRICAL ROOM MOTION					CIE132-Interior	
					N			
7	Alarm	WOMENS WASHROOM SMOKE					7110-FIRE - CALL PREM.	
					N			
8	Alarm	MENS WASHROOM SMOKE					7110-FIRE - CALL PREM.	
					N			
9	Alarm	MULTI PURPOSE ROOM 1 DOOR					CIE131-Perimeter	
					N			
10	Alarm	MULTI PURPOSE ROOM 2 DOOR					CIE131-Perimeter	
					N			
11	Alarm	CORNER STORAGE DOOR					CIE131-Perimeter	
					N			
12	Alarm	MIDDLE DOOR					CIE131-Perimeter	
					N			
CS# 112110			System Type WINC Radio Communicator					
ATI Hours		26	Minutes	ATI Late Event# W-NOTT		Active Date 6/6/2016		
Alt ATI Hours			Minutes	ATI Global				
ATI Option				ATI Page				
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?	Equipment	Type	
1	Alarm	Siren Trip					151-BURGLAR ALARM	
					N			
801	Alarm						302-WINC LOW BATTERY	
					N			
809	Alarm						301-WINC POWER LOSS	
					N			

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 132110			System Type WINC Radio Communicator					
ATI Hours		26	Minutes		ATI Late Event# G-NOTT		Active Date 10/16/2018	
Alt ATI Hours			Minutes		ATI Global			
ATI Option					ATI Page			
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?		Equipment Type	
1	Alarm	KITCHEN MOTION					CIE132-Interior	
					N			
2	Alarm	MULTI PURPOSE ROOM 1 MOTION					CIE132-Interior	
					N			
3	Alarm	MULTI PURPOSE ROOM 2 MOTION					CIE132-Interior	
					N			
4	Alarm	CORNER STORAGE MOTION					CIE132-Interior	
					N			
5	Alarm	MIDDLE STORAGE MOTION					CIE132-Interior	
					N			
6	Alarm	ELECTRICAL ROOM MOTION					CIE132-Interior	
					N			
7	Alarm	Mens Washroom Smoke					33-FIRE - DISPATCH 1ST	
					N			
8	Alarm	Ladies Washroom Smoke					33-FIRE - DISPATCH 1ST	
					N			
9	Alarm	Kitchen Door					CIE131-Perimeter	
					N			
10	Alarm	MULTI PURPOSE ROOM 2 DOOR					CIE131-Perimeter	
					N			
11	Alarm	SW Storage Room Door					CIE131-Perimeter	
					N			
12	Alarm	South Storage Room Door					CIE131-Perimeter	
					N			
17	Alarm	Boiler Room Door					CIE131-Perimeter	
					N			
O/C	Armed						SE-05-LOG ONLY CLOSE	
	1				N			
O/C	Disarm						SE-04-LOG ONLY OPEN	
	1				N			
CS# 281551			System Type VIST21 Vista 21 Internet					
ATI Hours		Minutes		ATI Late Event#		Active Date		
Alt ATI Hours		Minutes		ATI Global				
ATI Option				ATI Page				

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000203	CITY OF COQUITLAM 630 POIRIER STREET POIRIER COMMUNITY CENTRE(FIRE) COQUITLAM, BC V3J 6B1	Pacific Time Zone Yes		ULC Account Active	
		Cross Street Codewords			
Installing Company		3811-COQUITLAM ULC ACCOUNT		Corporate Account	2026-CITY OF COQUITLAM
Agency#-Name/Comment		Address		Service Company	3811-COQUITLAM ULC ACCOUNT
		Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

?

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last	CS# First to Last	Corporate Account 2026
CS# 22F211	System Type VIST32 Vista 32 FB Fire panel	
ATI Hours	Minutes	ATI Late Event#
Alt ATI Hours	Minutes	ATI Global
ATI Option		ATI Page
		Active Date

CS# 11F211	System Type WINC Radio Communicator	
ATI Hours 26	Minutes	ATI Late Event# W-NOTT
Alt ATI Hours	Minutes	ATI Global
ATI Option		ATI Page
Zone	State	Location/Comment
GL Sch	Sch#	Alarm Group
801	Alarm	
		Page GL Page Event
		Restore? Equipment Type
		N 302-WINC LOW BATTERY
809	Alarm	
		N 301-WINC POWER LOSS

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 13F211			System Type WINC Radio Communicator					
ATI Hours		26	Minutes		ATI Late Event#	G-NOTT	Active Date 2/20/2018	
Alt ATI Hours			Minutes		ATI Global			
ATI Option					ATI Page			
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?		Equipment	Type
1	Alarm						33-FIRE - DISPATCH 1ST	
					Y			
1	Trouble						CIE373-FIRE TROUBLE	
					Y			
2	Alarm						CIE373-FIRE TROUBLE	
					Y			
2	Trouble						CIE373-FIRE TROUBLE	
					Y			
3	Alarm						CIE200-FIRE SUPERVISORY Alert	
					Y			
3	Trouble						CIE373-FIRE TROUBLE	
					Y			
E333	Trouble	Cell Failure					850-TROUBLE	
					N			
R333	Restore	Cell Failure Restore					2000-RESTORE	
					N			
CS# 281486			System Type ANETG Alarmnet GSM Radio					
ATI Hours		26	Minutes		ATI Late Event#	G-NOTT	Active Date 2/14/2018	
Alt ATI Hours			Minutes		ATI Global			
ATI Option					ATI Page			
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?		Equipment	Type
1	Alarm						33-FIRE - DISPATCH 1ST	
					Y			
1	Trouble						CIE373-FIRE TROUBLE	
					Y			
2	Alarm						CIE373-FIRE TROUBLE	
					Y			
2	Trouble						CIE373-FIRE TROUBLE	
					Y			
3	Alarm						CIE200-FIRE SUPERVISORY Alert	
					Y			
3	Trouble						CIE373-FIRE TROUBLE	
					Y			
4	Alarm	Intellitap Trouble					850-TROUBLE	
					N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000208	CITY OF COQUITLAM 500 MARINER WAY PARKS ADMIN BUILDING COQUITLAM, BC V3B 7N2 604-927-6061	Pacific Time Zone Yes Cross Street Codewords		Commercial Active	
Installing Company 3511-COQUITLAM COMMERCIAL		Corporate Account 2026-CITY OF COQUITLAM		Service Company 3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last

CS# First to Last

Corporate Account 2026

?

Installer# First to Last

CS# First to Last

Corporate Account 2026

?

Installer#	First to Last	CS#	First to Last	Corporate Account	2026
Gen Dispatch	Permanent	Effective Date	12/31/2020 13:01	Expire Date	
CALL ALL PRS BEFORE DISPATCHING PD. CALL					
LIST RESPONDER WILL DECIDE IF PD IS					

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 221745		System Type V128 Vista 128						
ATI Hours		Minutes		ATI Late Event#		Active Date		
Alt ATI Hours		Minutes		ATI Global				
ATI Option				ATI Page				
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?	Equipment	Type	
1	Alarm	Middle North Entry Door					CIE134-Entry/Exit	
					N			
2	Alarm	Entry Motion					CIE132-Interior	
					N			
3	Alarm	Northwest Motion					CIE132-Interior	
					N			
4	Alarm	Rear Southwest Motion					CIE132-Interior	
					N			
5	Alarm	Rear Southeast Motion					CIE132-Interior	
					N			
6	Alarm	West Back Door					CIE131-Perimeter	
					N			
10	Alarm	Lunch Room Motion					CIE132-Interior	
					N			
11	Alarm	Lunch Room Door					CIE131-Perimeter	
					N			
12	Alarm	Locker Motion					CIE132-Interior	
					N			
13	Alarm	Locker Door					CIE131-Perimeter	
					N			
O/C	Armed						SE-05-LOG ONLY CLOSE	
	1				N			
O/C	Disarm						SE-04-LOG ONLY OPEN	
	1				N			

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last

CS# First to Last

Corporate Account 2026

CS# 281520		System Type ANETG Alarmnet GSM Radio				
ATI Hours 26		Minutes	ATI Late Event# G-NOTT		Active Date 6/5/2018	
Alt ATI Hours		Minutes	ATI Global			
ATI Option 2-Timer Test Only			ATI Page			
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment Type		
1	Alarm	Middle North Entry Door	N		CIE134-Entry/Exit	
2	Alarm	Entry Motion	N		CIE132-Interior	
3	Alarm	Northwest Motion	N		CIE132-Interior	
4	Alarm	Rear Southwest Motion	N		CIE132-Interior	
5	Alarm	Rear Southeast Motion	N		CIE132-Interior	
6	Alarm	West Back Door	N		CIE131-Perimeter	
10	Alarm	Lunch Room Motion	N		CIE132-Interior	
11	Alarm	Lunch Room Door	N		CIE131-Perimeter	
12	Alarm	Locker Motion	N		CIE132-Interior	
13	Alarm	Locker Door	N		CIE131-Perimeter	
O/C	Armed		N		SE-05-LOG ONLY CLOSE	
	1		N			
O/C	Disarm		N		SE-04-LOG ONLY OPEN	
	1		N			

Installer# First to Last		CS# First to Last	Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status
10000210	CITY OF COQUITLAM	Pacific Time Zone		ULC Account
	1200 GLEN PINE COURT	Yes		Active
	GLEN PINE	Cross Street		
	COQUITLAM, BC V3B 2P7	Codewords		
	604-927-6068	Corporate Account	2026-CITY OF COQUITLAM	
Installing Company	3811-COQUITLAM ULC ACCOUNT	Service Company	3811-COQUITLAM ULC ACCOUNT	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2
10-COQUITLAM PD		P	604-464-6211	
71-COQUITLAM FD		F	604-215-4826	

Gen Dispatch Permanent **Effective Date** 12/11/2018 13:35 **Expire Date**
NO DISPATCH INSTALL PENDING

CS# 22F250 **System Type** WINC Radio Communicator

ATI Hours	Minutes	ATI Late Event#	Active Date
Alt ATI Hours	Minutes	ATI Global	
ATI Option		ATI Page	

CS# 11F250 **System Type** WINC Radio Communicator

ATI Hours	Minutes	ATI Late Event# W-NOTT	Active Date 7/17/2018
Alt ATI Hours	Minutes	ATI Global	
ATI Option		ATI Page	

CS# 12F250 **System Type** WINC Radio Communicator

ATI Hours	6	Minutes	ATI Late Event# W-NOTT	Active Date
Alt ATI Hours		Minutes	ATI Global	
ATI Option			ATI Page	

Installer# First to Last		CS# First to Last		Corporate Account 2026			
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status			
10000210	CITY OF COQUITLAM	Pacific Time Zone		Commercial			
	3000 GUILDFORD WAY	Yes		Active			
	CITY HALL FIRE MONITORING	Cross Street					
	COQUITLAM, BC V3B 7N2	Codewords					
	604-927-3650	604-927-6520		Corporate Account	2026-CITY OF COQUITLAM		
	Installing Company	3511-COQUITLAM COMMERCIAL		Service Company	3511-COQUITLAM COMMERCIAL		
Agency#-Name/Comment		Address		Type	Phone 1	Phone 2	
10-COQUITLAM PD				P	604-464-6211		
71-COQUITLAM FD				F	604-215-4826		
Contact Name	CS Seq	Contact Type		Relation		Call List	
Contact#	Authority	Keys?	PIN			Site Dates	Verify?
Elevator 3							
49685			N			5/26/2021-Permanent	N
Phone/Email		Ext	Type	Call Days	Times	Except?	Inactive
604-927-6522						N	
Elevator 4							
49686			N			5/26/2021-Permanent	N
Phone/Email		Ext	Type	Call Days	Times	Except?	Inactive
604-927-6521						N	

Elevator 1	60						
52192			N				6/8/2022-Permanent
Phone/Email		Ext	Type	Call Days	Times	Except?	Inactive
604-927-6580						N	

Installer# First to Last **CS#** First to Last **Corporate Account** 2026
Gen Dispatch Permanent **Effective Date** 2/11/2021 16:48 **Expire Date**
 PR TO DETERMINE IF PD IS REQUIRED,
 OTHERWISE DO NOT SEND PD

CS# 22F249		System Type VIST32 Vista 32 FB Fire panel			
ATI Hours	26	Minutes		ATI Late Event# G-NOTT	Active Date 3/22/2021
Alt ATI Hours		Minutes		ATI Global	
ATI Option				ATI Page	
Zone	State	Location/Comment		Page	GL Page Event
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm				33-FIRE - DISPATCH 1ST
				Y	
1	Trouble				CIE373-FIRE TROUBLE
				Y	
2	Alarm				CIE373-FIRE TROUBLE
				Y	
2	Trouble				CIE373-FIRE TROUBLE
				Y	
E333	Alarm	Cell Failure			850-TROUBLE
				N	
R333	Restore	Cell Failure Restore			2000-RESTORE
				N	
CS# 281775		System Type ANETG Alarmnet GSM Radio			
ATI Hours	26	Minutes		ATI Late Event# W-NOTT	Active Date 2/11/2021
Alt ATI Hours		Minutes		ATI Global	
ATI Option				ATI Page	
Zone	State	Location/Comment		Page	GL Page Event
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm				33-FIRE - DISPATCH 1ST
				Y	
1	Trouble				CIE373-FIRE TROUBLE
				Y	
2	Alarm				CIE373-FIRE TROUBLE
				Y	
2	Trouble				CIE373-FIRE TROUBLE
				Y	
E333	Trouble	Cell Failure			850-TROUBLE
				N	
R333	Restore	Cell Failure Restore			2000-RESTORE
				N	

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000219	CITY OF COQUITLAM 633 POIRIER STREET AMMONIA PLANT AT SPORTS LEISUR COQUITLAM, BC V3B 7N2	Pacific Time Zone Yes Cross Street Codewords		Commercial Active	
Installing Company 3511-COQUITLAM COMMERCIAL		Corporate Account 2026-CITY OF COQUITLAM		Service Company 3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

?

Gen Dispatch Permanent **Effective Date** 4/17/2019 16:01 **Expire Date**

CRITICAL AMMONIA ALARMS -
MUST NOTIFY PR IMMEDIATELY!
DISPATCH FD IF NO RESPONSE
FROM PR ON ZONE 1 HIGH AMMONIA
- CUSTOMER MUST PUNCH 1234 + 1

CS# 22F272 **System Type** VIST32 Vista 32 FB Fire panel

ATI Hours	Minutes	ATI Late Event#	Active Date
Alt ATI Hours	Minutes	ATI Global	
ATI Option		ATI Page	

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 281589			System Type ANETG Alarmnet GSM Radio					
ATI Hours		26	Minutes		ATI Late Event#	G-NOTT	Active Date 4/17/2019	
Alt ATI Hours			Minutes		ATI Global			
ATI Option					ATI Page			
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?	Equipment	Type	
1	Alarm	*CRITICAL*High Ammonia Alarm - NOTIF\					CRIT-Critical Event	
					Y			
1	Trouble	*CRITICAL*High Ammonia Alarm - NOTIF\					CIE373-FIRE TROUBLE	
					Y			
2	Alarm	Plant Alarm - Notify PR					7150-24 HR NON-BURGLARY	
					Y			
2	Trouble	Plant Alarm - Notify PR					CIE373-FIRE TROUBLE	
					Y			
3	Alarm	Fan Failure - Notify PR					7150-24 HR NON-BURGLARY	
					Y			
3	Trouble	Fan Failure - Notify PR					CIE373-FIRE TROUBLE	
					Y			
5	Trouble	Intellitap Fail					850-TROUBLE	
					N			
CS# 11F272			System Type WINC Radio Communicator					
ATI Hours		26	Minutes		ATI Late Event#	G-NOTT	Active Date 4/17/2019	
Alt ATI Hours			Minutes		ATI Global			
ATI Option					ATI Page			
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?	Equipment	Type	
801	Trouble						302-WINC LOW BATTERY	
					N			
809	Trouble						301-WINC POWER LOSS	
					N			
CS# 13F272			System Type WINC Radio Communicator					
ATI Hours		26	Minutes		ATI Late Event#	G-NOTT	Active Date 4/17/2019	
Alt ATI Hours			Minutes		ATI Global			
ATI Option					ATI Page			
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?	Equipment	Type	
1	Alarm	*CRITICAL*High Ammonia Alarm - NOTIF\					CRIT-Critical Event	
					Y			
1	Trouble	*CRITICAL*High Ammonia Alarm - NOTIF\					CIE373-FIRE TROUBLE	
					Y			
2	Alarm	Plant Alarm - Notify PR					7150-24 HR NON-BURGLARY	
					Y			
2	Trouble	Plant Alarm - Notify PR					CIE373-FIRE TROUBLE	
					Y			
3	Alarm	Fan Failure - Notify PR					7150-24 HR NON-BURGLARY	
					Y			
3	Trouble	Fan Failure - Notify PR					CIE373-FIRE TROUBLE	
					Y			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000229	CITY OF COQUITLAM 644 POIRIER STREET 1ST FLOOR COQUITLAM, BC V3J 6B1	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Gen Dispatch Permanent **Effective Date** 12/31/2020 13:04 **Expire Date**

CALL ALL PRS BEFORE DISPATCHING PD. CALL
LIST RESPONDER WILL DECIDE IF PD IS

Dispatch Page# 1-Permanent Vaccine Alarms

Effective 3/8/2022 14:16 **Expires**

Service Types TRBLE

Site Type C

Site Status A

System Type

Continue Page

Sun Y

Mon Y

Tue Y

Wed Y

Thu Y

Fri Y

Sat Y

Only

Sched#

GL Sched

CRITICAL ALARMS TIED TO VACCINE
STORAGE REFRIGERATOR -
CONTACT FRASER HEALTH CALL LIST
AND ADVISE IMMEDIATELY

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 221910		System Type V128 Vista 128		Active Date 3/10/2021	
ATI Hours	Minutes	ATI Late Event#			
Alt ATI Hours	Minutes	ATI Global			
ATI Option		ATI Page			
Zone	State	Location/Comment		Page	GL Page Event
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
7	Alarm	Ac Failure		1	CRIT-Critical Event
				N	
7	Trouble	Ac Failure		1	CRIT-Critical Event
				N	
8	Alarm	Vaccine Fridge Failure		1	CRIT-Critical Event
				N	
8	Trouble	Vaccine Fridge Failure		1	CRIT-Critical Event
				N	
10	Alarm	Side Entry Motion			CIE132-Interior
				N	
11	Alarm	Side Entry Door			CIE134-Entry/Exit
				N	
12	Alarm	Rear Door Motion			CIE132-Interior
				N	
13	Alarm	Rear Door			CIE131-Perimeter
				N	
14	Alarm	Front Northeast Office Motion			CIE132-Interior
				N	
15	Alarm	Hall Door By Washrooms			CIE131-Perimeter
				N	
16	Alarm	Hall Motion by Washrooms			CIE132-Interior
				N	
17	Alarm	Front East Middle Interior Entry Door			CIE134-Entry/Exit
				N	
18	Alarm	Front East Middle Entry Door Motion			CIE132-Interior
				N	
O/C	Armed				SE-05-LOG ONLY CLOSE
	1			N	
O/C	Disarm				SE-04-LOG ONLY OPEN
	1			N	

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 281675			System Type ANETG Alarmnet GSM Radio					
ATI Hours 26		Minutes	ATI Late Event# G-NOTT		Active Date 4/20/2020			
Alt ATI Hours		Minutes	ATI Global					
ATI Option 2-Timer Test Only			ATI Page					
Zone	State	Location/Comment		Page	GL Page	Event		
GL Sch	Sch#	Alarm Group		Restore?	Equipment	Type		
10	Alarm	Side Entry Motion				CIE132-Interior		
				N				
11	Alarm	Side Entry Door				CIE134-Entry/Exit		
				N				
12	Alarm	Rear Door Motion				CIE132-Interior		
				N				
13	Alarm	Rear Door				CIE131-Perimeter		
				N				
14	Alarm	Front Northeast Office Motion				CIE132-Interior		
				N				
15	Alarm	Hall Door By Washrooms				CIE131-Perimeter		
				N				
16	Alarm	Hall Motion by Washrooms				CIE132-Interior		
				N				
17	Alarm	Front East Middle Interior Entry Door				CIE134-Entry/Exit		
				N				
18	Alarm	Front East Middle Entry Door Motion				CIE132-Interior		
				N				
19	Alarm	Ac Failure - Notify Fraser Health ASAP!		1		CRIT-Critical Event		
				N				
19	Trouble	Ac Failure - Notify Fraser Health ASAP!		1		CRIT-Critical Event		
				N				
20	Alarm	Vaccine Fridge 1 Fail - Notify Fraser Health		1		CRIT-Critical Event		
				N				
20	Trouble	Vaccine Fridge 1 Fail - Notify Fraser Health		1		CRIT-Critical Event		
				N				
21	Alarm	Vaccine Fridge 2 Fail - Notify Fraser Health		1		CRIT-Critical Event		
				N				
21	Trouble	Vaccine Fridge 2 Fail - Notify Fraser Health		1		CRIT-Critical Event		
				N				
O/C	Armed					SE-05-LOG ONLY CLOSE		
	1			N				
O/C	Disarm					SE-04-LOG ONLY OPEN		
	1			N				

Installer# First to Last		CS# First to Last	Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings	Site Type/Status	
10000235	CITY OF COQUITLAM	Pacific Time Zone	Commercial	
	640 POIRIER STREET	Yes	Active	
	EXPRESS OFFICE	Cross Street		
	COQUITLAM, BC V3B 7N2	Codewords		
Installing Company 3511-COQUITLAM COMMERCIAL		Corporate Account	2026-CITY OF COQUITLAM	
		Service Company	3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2
10-COQUITLAM PD		P	604-464-6211	
71-COQUITLAM FD		F	604-215-4826	

Gen Dispatch Permanent **Effective Date** 12/31/2020 13:02 **Expire Date**

CALL ALL PRS BEFORE DISPATCHING PD. CALL
LIST RESPONDER WILL DECIDE IF PD IS

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 221959		System Type V128 Vista 128						
ATI Hours		Minutes	ATI Late Event#		Active Date			
Alt ATI Hours		Minutes	ATI Global					
ATI Option			ATI Page					
Zone	State	Location/Comment		Page	GL Page	Event		
GL Sch	Sch#	Alarm Group		Restore?	Equipment	Type		
1	Alarm	Front Door				CIE134-Entry/Exit		
				N				
2	Alarm	Reception Motion				CIE132-Interior		
				N				
O/C	Armed					SE-05-LOG ONLY CLOSE		
	1			N				
O/C	Disarm					SE-04-LOG ONLY OPEN		
	1			N				

CS# 281734			System Type ANETG Alarmnet GSM Radio					
ATI Hours		26	Minutes	ATI Late Event# G-NOTT		Active Date 11/24/2020		
Alt ATI Hours			Minutes	ATI Global				
ATI Option				ATI Page				
Zone	State	Location/Comment		Page	GL Page	Event		
GL Sch	Sch#	Alarm Group		Restore?	Equipment	Type		
1	Alarm	Front Door				CIE134-Entry/Exit		
				N				
2	Alarm	Reception Motion				CIE132-Interior		
				N				
O/C	Armed					SE-05-LOG ONLY CLOSE		
	1			N				
O/C	Disarm					SE-04-LOG ONLY OPEN		
	1			N				

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000244	CITY OF COQUITLAM 3537 PRINCETON AVENUE BURKE MOUNTAIN DISCOVERY FIRE COQUITLAM, BC V3B 7N2	Pacific Time Zone Yes Cross Street Codewords		ULC Account Active	
Installing Company 3811-COQUITLAM ULC ACCOUNT		Corporate Account 2026-CITY OF COQUITLAM		Service Company 3811-COQUITLAM ULC ACCOUNT	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

/?

Gen Dispatch Permanent Effective Date 7/27/2021 12:24 Expire Date

CS# 22F342		System Type VIST32 Vista 32 FB Fire panel			
ATI Hours	26	Minutes	ATI Late Event# G-NOTT	Active Date 10/6/2021	
Alt ATI Hours		Minutes	ATI Global		
ATI Option			ATI Page		
Zone	State	Location/Comment	Page	GL Page	Event
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type
1	Alarm				33-FIRE - DISPATCH 1ST
			Y		
1	Trouble				CIE373-FIRE TROUBLE
			Y		
2	Alarm				CIE373-FIRE TROUBLE
			Y		
2	Trouble				CIE373-FIRE TROUBLE
			Y		
3	Alarm				CIE200-FIRE SUPERVISORY Alert
			Y		
3	Trouble				CIE373-FIRE TROUBLE
			Y		
E333	Trouble	Cell Failure			850-TROUBLE
			N		
R333	Restore	Cell Failure Restore			2000-RESTORE
			N		

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 281839			System Type ANETG Alarmnet GSM Radio					
ATI Hours		26	Minutes		ATI Late Event# G-NOTT		Active Date 7/27/2021	
Alt ATI Hours			Minutes		ATI Global			
ATI Option					ATI Page			
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?		Equipment Type	
1	Alarm						33-FIRE - DISPATCH 1ST	
					Y			
1	Trouble						CIE373-FIRE TROUBLE	
					Y			
2	Alarm						CIE373-FIRE TROUBLE	
					Y			
2	Trouble						CIE373-FIRE TROUBLE	
					Y			
3	Alarm						CIE200-FIRE SUPERVISORY Alert	
					Y			
3	Trouble						CIE373-FIRE TROUBLE	
					Y			
E333	Trouble	Cell Failure					850-TROUBLE	
					N			
R333	Restore	Cell Failure Restore					2000-RESTORE	
					N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000246	CITY OF COQUITLAM 3537 PRINCETON AVENUE BURKE MOUNTAIN DISCOVERY BURG COQUITLAM, BC V3B 7N2	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company		Corporate Account		2026-CITY OF COQUITLAM	
3511-COQUITLAM COMMERCIAL		Service Company		3511-COQUITLAM COMMERCIAL	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

P1= Coffee Shop
P2= City Area

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 220176		System Type V128 Vista 128		Active Date 9/28/2021	
ATI Hours	Minutes	ATI Late Event#			
Alt ATI Hours	Minutes	ATI Global			
ATI Option		ATI Page			
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Equipment Type
1	Alarm	Front Southwest Door			CIE134-Entry/Exit
				N	
2	Alarm	Front Southeast Door			CIE134-Entry/Exit
				N	
3	Alarm	Rear North Door			CIE131-Perimeter
				N	
4	Alarm	Rear South Door			CIE131-Perimeter
				N	
5	Alarm	Southeast Entry Door			CIE134-Entry/Exit
				N	
6	Alarm	Electrical Room Door			CIE131-Perimeter
				N	
7	Alarm	Interior East Door			CIE131-Perimeter
				N	
8	Alarm	Kitchen Glassbreak			CIE131-Perimeter
				N	
9	Alarm	Kitchen 360 Motion			CIE132-Interior
				N	
17	Alarm	Interior West Door			CIE131-Perimeter
				N	
18	Alarm	Rear Hall Motion			CIE132-Interior
				N	
19	Alarm	Backroom 360 Motion			CIE132-Interior
				N	
20	Alarm	Southeast Room 360 Motion			CIE132-Interior
				N	
21	Alarm	Southeast Rear Room Glassbreak			CIE131-Perimeter
				N	
22	Alarm	Southwest Rear Room Glassbreak			CIE131-Perimeter
				N	
23	Alarm	Northwest Rear Room Glassbreak			CIE131-Perimeter
				N	
24	Alarm	Front Southeast Glassbreak			CIE131-Perimeter
				N	
25	Alarm	Front East 360 Motion			CIE132-Interior
				N	
26	Alarm	Front West 360 Motion			CIE132-Interior
				N	
27	Alarm	Front South Glassbreak			CIE131-Perimeter
				N	
28	Alarm	Front Southwest Glassbreak			CIE131-Perimeter
				N	
29	Alarm	Front Northwest Glassbreak			CIE131-Perimeter
				N	

Installer# First to Last

CS# First to Last

Corporate Account 2026

Installer# First to Last		CS# First to Last		Corporate Account 2026	
CS# 281846		System Type ANETG Alarmnet GSM Radio			
ATI Hours 26		Minutes		ATI Late Event# G-NOTT	
Alt ATI Hours		Minutes		Active Date 8/19/2021	
ATI Option		ATI Global		ATI Page	
Zone	State	Location/Comment		Page	GL Page
GL Sch	Sch#	Alarm Group		Restore?	Event
					Equipment Type
1	Alarm	Front Southwest Door			CIE134-Entry/Exit
				N	
2	Alarm	Front Southeast Door			CIE134-Entry/Exit
				N	
3	Alarm	Rear North Door			CIE131-Perimeter
				N	
4	Alarm	Rear South Door			CIE131-Perimeter
				N	
5	Alarm	Southeast Entry Door			CIE134-Entry/Exit
				N	
6	Alarm	Electrical Room Door			CIE131-Perimeter
				N	
7	Alarm	Interior East Door			CIE131-Perimeter
				N	
8	Alarm	Kitchen Glassbreak			CIE131-Perimeter
				N	
9	Alarm	Kitchen 360 Motion			CIE132-Interior
				N	
17	Alarm	Interior West Door			CIE131-Perimeter
				N	
18	Alarm	Rear Hall Motion			CIE132-Interior
				N	
19	Alarm	Backroom 360 Motion			CIE132-Interior
				N	
20	Alarm	Southeast Room 360 Motion			CIE132-Interior
				N	
21	Alarm	Southeast Rear Room Glassbreak			CIE131-Perimeter
				N	
22	Alarm	Southwest Rear Room Glassbreak			CIE131-Perimeter
				N	
23	Alarm	Northwest Rear Room Glassbreak			CIE131-Perimeter
				N	
24	Alarm	Front Southeast Glassbreak			CIE131-Perimeter
				N	
25	Alarm	Front East 360 Motion			CIE132-Interior
				N	
26	Alarm	Front West 360 Motion			CIE132-Interior
				N	
27	Alarm	Front South Glassbreak			CIE131-Perimeter
				N	
28	Alarm	Front Southwest Glassbreak			CIE131-Perimeter
				N	
29	Alarm	Front Northwest Glassbreak			CIE131-Perimeter
				N	
O/C-1	Armed	Coffee Shop			SE-05-LOG ONLY CLOSE
	1	Coffee Shop		N	
O/C-1	Disarm	Coffee Shop			SE-04-LOG ONLY OPEN
	1	Coffee Shop		N	
O/C-2	Armed	City Area			SE-05-LOG ONLY CLOSE
	2	City Area		N	

Installer# First to Last			CS# First to Last		Corporate Account 2026	
Zone	State	Location/Comment	Page	GL Page	Event	
GL Sch	Sch#	Alarm Group	Restore?	Equipment Type		
O/C-2	Disarm	City Area			SE-04-LOG ONLY OPEN	
	2	City Area	N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000248	CITY OF COQUITLAM 2986 GUILDFORD WAY RCMP - PUBLIC SAFETY BUILDING COQUITLAM, BC	Pacific Time Zone Yes Cross Street Codewords		ULC Account Active	
Installing Company 3811-COQUITLAM ULC ACCOUNT		Corporate Account 2026-CITY OF COQUITLAM		Service Company 3811-COQUITLAM ULC ACCOUNT	
Agency#-Name/Comment	Address	Type	Phone 1	Phone 2	
10-COQUITLAM PD		P	604-464-6211		
71-COQUITLAM FD		F	604-215-4826		

Gen Dispatch Permanent Effective Date 10/28/2021 13:03 Expire Date

CS# 22F355		System Type VIST32 Vista 32 FB Fire panel			
ATI Hours	26	Minutes	ATI Late Event# G-NOTT	Active Date 10/28/2021	
Alt ATI Hours		Minutes	ATI Global		
ATI Option			ATI Page		
Zone	State	Location/Comment	Page	GL Page	Event
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type
1	Alarm		Y		33-FIRE - DISPATCH 1ST
1	Trouble		Y		CIE373-FIRE TROUBLE
2	Alarm		Y		CIE373-FIRE TROUBLE
2	Trouble		Y		CIE373-FIRE TROUBLE
3	Alarm		Y		CIE200-FIRE SUPERVISORY Alert
3	Trouble		Y		CIE373-FIRE TROUBLE
E333	Trouble	Cell Failure	N		850-TROUBLE
R333	Restore	Cell Failure Restore	N		2000-RESTORE

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 281864			System Type ANETG Alarmnet GSM Radio					
ATI Hours		26	Minutes		ATI Late Event# G-NOTT		Active Date 10/28/2021	
Alt ATI Hours			Minutes		ATI Global			
ATI Option					ATI Page			
Zone	State	Location/Comment			Page	GL Page	Event	
GL Sch	Sch#	Alarm Group			Restore?		Equipment Type	
1	Alarm						33-FIRE - DISPATCH 1ST	
					Y			
1	Trouble						CIE373-FIRE TROUBLE	
					Y			
2	Alarm						CIE373-FIRE TROUBLE	
					Y			
2	Trouble						CIE373-FIRE TROUBLE	
					Y			
3	Alarm						CIE200-FIRE SUPERVISORY Alert	
					Y			
3	Trouble						CIE373-FIRE TROUBLE	
					Y			
E333	Trouble	Cell Failure					850-TROUBLE	
					N			
R333	Restore	Cell Failure Restore					2000-RESTORE	
					N			

Installer# First to Last		CS# First to Last		Corporate Account 2026	
Site#	Site Name & Address	Time Zone/Daylight Savings		Site Type/Status	
10000261	CITY OF COQUITLAM 1200 CARTIER AVENUE PLACE MAILLARDVILLE FIRE COQUITLAM, BC V3K 2C3	Pacific Time Zone Yes		Commercial Active	
		Cross Street Codewords			
Installing Company		3811-COQUITLAM ULC ACCOUNT		Corporate Account	2026-CITY OF COQUITLAM
Agency#-Name/Comment		Address		Service Company	3811-COQUITLAM ULC ACCOUNT
10-COQUITLAM PD				Type	Phone 1
71-COQUITLAM FD				P	604-464-6211
				F	604-215-4826
				Phone 2	

?

Gen Dispatch Permanent Effective Date 7/22/2022 15:22 Expire Date

Installer# First to Last			CS# First to Last			Corporate Account 2026		
CS# 22F378			System Type VIST32 Vista 32 FB Fire panel					
ATI Hours 26 Minutes			ATI Late Event# G-NOTT			Active Date 7/22/2022		
Alt ATI Hours Minutes			ATI Global					
ATI Option			ATI Page					
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
1	Alarm				33-FIRE - DISPATCH 1ST			
			Y					
1	Trouble				CIE373-FIRE TROUBLE			
			Y					
2	Alarm				CIE373-FIRE TROUBLE			
			Y					
2	Trouble				CIE373-FIRE TROUBLE			
			Y					
3	Alarm				CIE200-FIRE SUPERVISORY Alert			
			Y					
3	Trouble				CIE373-FIRE TROUBLE			
			Y					
4	Alarm	Waterflow			33-FIRE - DISPATCH 1ST			
			N					
4	Trouble	Waterflow			CIE373-FIRE TROUBLE			
			N					
E333	Trouble	Cell Failure			850-TROUBLE			
			N					
R333	Restore	Cell Failure Restore			2000-RESTORE			
			N					
CS# 281960			System Type ANETG Alarmnet GSM Radio					
ATI Hours 26 Minutes			ATI Late Event# G-NOTT			Active Date 7/22/2022		
Alt ATI Hours Minutes			ATI Global					
ATI Option			ATI Page					
Zone	State	Location/Comment	Page	GL Page	Event			
GL Sch	Sch#	Alarm Group	Restore?	Equipment	Type			
1	Alarm				33-FIRE - DISPATCH 1ST			
			Y					
1	Trouble				CIE373-FIRE TROUBLE			
			Y					
2	Alarm				CIE373-FIRE TROUBLE			
			Y					
2	Trouble				CIE373-FIRE TROUBLE			
			Y					
3	Alarm				CIE200-FIRE SUPERVISORY Alert			
			Y					
3	Trouble				CIE373-FIRE TROUBLE			
			Y					
4	Alarm	Waterflow			33-FIRE - DISPATCH 1ST			
			Y					
4	Trouble	Waterflow			CIE373-FIRE TROUBLE			
			Y					
E333	Trouble	Cell Failure			850-TROUBLE			
			N					
R333	Restore	Cell Failure Restore			2000-RESTORE			
			N					